



SIMATIC ET 200SP, analog input module, AI Energy Meter CT HF, for 1A or 5A current transformer, with network analysis functions, suitable for BU type U0, channel diagnostics

General information	
Product type designation	AI Energy Meter CT HF
Firmware version	V8.0
<ul style="list-style-type: none"> <li>FW update possible</li> </ul>	Yes
usable BaseUnits	BU type U0
Color code for module-specific color identification plate	CC20
Supported power supply systems	TT, TN, IT
Product function	
<ul style="list-style-type: none"> <li>Voltage measurement                             <ul style="list-style-type: none"> <li>— without voltage transformer</li> <li>— with voltage transformer</li> </ul> </li> <li>Current measurement                             <ul style="list-style-type: none"> <li>— without current transformer</li> <li>— with current transformer</li> <li>— With Rogowski coil</li> <li>— With current-voltage-converter</li> </ul> </li> <li>Energy measurement</li> <li>Frequency measurement</li> <li>Power measurement</li> <li>Active power measurement</li> <li>Reactive power measurement</li> <li>Power factor measurement</li> <li>Active factor measurement</li> <li>Reactive power compensation</li> <li>Line analysis                             <ul style="list-style-type: none"> <li>— Monitoring of instantaneous and half-wave values</li> <li>— THD measurement for current and voltage</li> <li>— Harmonics for current and voltage</li> <li>— Voltage dip (DIP)</li> <li>— Voltage swell</li> </ul> </li> <li>I&amp;M data</li> <li>Isochronous mode</li> </ul>	<p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes; Max. 4</p> <p>No</p> <p>Yes; 1 A or 5 A current transformer</p> <p>No</p> <p>No</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes; I&amp;M0 to I&amp;M3</p> <p>No</p>
Engineering with	
<ul style="list-style-type: none"> <li>STEP 7 TIA Portal configurable/integrated from version</li> <li>STEP 7 configurable/integrated from version</li> <li>PROFIBUS from GSD version/GSD revision</li> <li>PROFINET from GSD version/GSD revision</li> </ul>	<p>STEP 7 V16 or higher with HSP</p> <p>V5.5 SP3 or higher</p> <p>One GSD file each, Revision 3 and 5 and higher</p> <p>V2.3</p>
Operating mode	

<ul style="list-style-type: none"> <li>• Switching between operating modes in RUN</li> </ul>	Yes; For module version 32 I/20 Q, it is possible to dynamically switch between 25 user data variants, 23 of which are pre-defined and 2 of which can be defined by the specific user
<ul style="list-style-type: none"> <li>• Cyclic measured value access</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Acyclic measured value access</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Fixed measured value sets</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Freely definable measured value sets</li> </ul>	Yes; For cyclic and acyclic measured value access
<b>CiR - Configuration in RUN</b>	
Reparameterization possible in RUN	Yes
Calibration possible in RUN	Yes
<b>Installation type/mounting</b>	
Mounting position	any
<b>Supply voltage</b>	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
<b>Input current</b>	
Current consumption (rated value)	12.5 mA
Current consumption, max.	17 mA
<b>Power loss</b>	
Power loss, typ.	1.4 W; 4x 6 A input current, 3x 230 V AC
<b>Address area</b>	
Address space per module	
<ul style="list-style-type: none"> <li>• Inputs</li> </ul>	256 byte
<ul style="list-style-type: none"> <li>• Outputs</li> </ul>	20 byte
<b>Hardware configuration</b>	
Automatic encoding	Yes
<ul style="list-style-type: none"> <li>• Mechanical coding element</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Type of mechanical coding element</li> </ul>	type C
<b>Selection of BaseUnit for connection variants</b>	
<ul style="list-style-type: none"> <li>• 2-wire connection</li> </ul>	BU type U0
<b>Time of day</b>	
Operating hours counter	
<ul style="list-style-type: none"> <li>• present</li> </ul>	Yes
<b>Analog inputs</b>	
Cycle time (all channels), typ.	50 ms; Time for consistent update of all measured and calculated values (cyclic und acyclic data)
<b>Cable length</b>	
<ul style="list-style-type: none"> <li>• shielded, max.</li> </ul>	200 m
<ul style="list-style-type: none"> <li>• unshielded, max.</li> </ul>	200 m
<b>Analog value generation for the inputs</b>	
Sampling frequency, max.	2 048 kHz
<b>Interrupts/diagnostics/status information</b>	
<b>Alarms</b>	
<ul style="list-style-type: none"> <li>• Diagnostic alarm</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Limit value alarm</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Hardware interrupt</li> </ul>	Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)
<b>Diagnoses</b>	
<ul style="list-style-type: none"> <li>• Line quality</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Supply voltage</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Hardware interrupt lost</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Parameter assignment error</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Module fault</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Channel not available</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Overflow/underflow</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Overload current</li> </ul>	Yes
<b>Diagnostics indication LED</b>	
<ul style="list-style-type: none"> <li>• Monitoring of the supply voltage (PWR-LED)</li> </ul>	Yes

• Channel status display	Yes; green LED
• for channel diagnostics	Yes; red Fn LED
• for module diagnostics	Yes; green/red DIAG LED

## Integrated Functions

<b>Measuring functions</b>	
• Measuring procedure for voltage measurement	TRMS
• Measuring procedure for current measurement	TRMS
• Type of measured value acquisition	seamless
• Curve shape of voltage	Sinusoidal or distorted
• Buffering of measured variables	Yes
• Parameter length	128 byte
• Bandwidth of measured value acquisition	3.2 kHz; Harmonics: 63 / 50 Hz, 52 / 60 Hz
<b>Measuring range</b>	
— Frequency measurement, min.	40 Hz
— Frequency measurement, max.	70 Hz
<b>Measuring inputs for voltage</b>	
— Measurable line voltage between phase and neutral conductor	277 V
— Measurable line voltage between the line conductors	480 V
— Measurable line voltage between phase and neutral conductor, min.	3 V
— Measurable line voltage between phase and neutral conductor, max.	300 V
— Measurable line voltage between the line conductors, min.	6 V
— Measurable line voltage between the line conductors, max.	519 V
— Internal resistance line conductor and neutral conductor	1.5 MΩ
— Power consumption per phase	60 mW; 300 V AC
— Impulse voltage resistance 1,2/50μs	2.5 kV
— Measurement category for voltage measurement in accordance with IEC 61010-2-030	CAT II
<b>Measuring inputs for current</b>	
— measurable relative current (AC), min.	1 %; Relative to measuring range; 1 A, 5 A
— measurable relative current (AC), max.	120 %; Relative to the secondary rated current 5 A
— Continuous current with AC, maximum permissible	5 A; 6 A permanent thermal overload
— Apparent power consumption per phase for measuring range 5 A	0.6 VA
— Rated value short-time withstand current restricted to 1 s	100 A
— Input resistance measuring range 0 to 5 A	25 mΩ; At the terminal
— Surge strength	10 A; for 1 minute
— Zero point suppression	0 ... 20%, referred to the nominal current
<b>Accuracy class according to IEC 61557-12</b>	
— Measured variable voltage	0,2
— Measured variable current	0,2
— Measured variable apparent power	0.5
— Measured variable active power	0.5
— Measured variable reactive power	1
— Measured variable power factor	0.5
— Measured variable active energy	0.5
— Measured variable reactive energy	1
— Measured variable neutral current	0,2
— Measured variable phase angle	±0.5 °; not covered by IEC 61557-12
— Measured variable frequency	0.05; only valid for the permissible voltage measuring range
— Measured variable harmonic	1
— Measured variable THDU	1
— Measured variable THDI	1
Accuracy class line analysis acc. to IEC 61000-4-30	

— Measured variable voltage	Class S
— Measured variable current	Class S
— Measured variable frequency	Class S
— Measured variable voltage interruption	Class S
— Measured variable voltage dip and swell	Class S
— Measured variable harmonic voltage	Class S
— Measured variable harmonic current	Class S

### Potential separation

#### Potential separation channels

• between the channels	No
• between the channels and backplane bus	Yes
• Between the channels and load voltage L+	Yes; Including FE

### Isolation

Isolation tested with	Between channels and backplane bus, 24 V supply: Routine test, 1 920 V AC, 2 s; between backplane bus and 24 V supply: Type test, 707 V DC
-----------------------	--

### Ambient conditions

#### Ambient temperature during operation

• horizontal installation, min.	-30 °C
• horizontal installation, max.	60 °C
• vertical installation, min.	-30 °C
• vertical installation, max.	50 °C

#### Altitude during operation relating to sea level

• Installation altitude above sea level, max.	3 000 m; Restrictions for installation altitudes > 2 000 m, see manual
---	--

### Dimensions

Width	20 mm
Height	73 mm
Depth	58 mm

### Weights

Weight, approx.	45 g
-----------------	------

### Other

#### Data for selecting a voltage transformer

• Secondary side, max.	300 V
------------------------	-------

#### Data for selecting a current transformer

• Burden power current transformer x/1A, min.	As a function of cable length and cross section, see device manual
• Burden power current transformer x/5A, min.	As a function of cable length and cross section, see device manual

**last modified:** 12/28/2021 