SIEMENS

product brand name

Data sheet 3UG4633-1AL30

SIRIUS



Digital monitoring relay Voltage monitoring, 22.5 mm from 17-275 V AC/DC Overshoot and undershoot Self-powered Spike delay 0.1 to 20 s Hysteresis 0.1 to 150 V 1 CO contact With or without error buffer Screw terminals Successor product for 3UG3534, 3UG3535

product brand name	311103		
product designation	Voltage monitoring relay with digital setting		
product type designation	3UG4		
General technical data			
product function	Voltage monitoring relay		
design of the display	LCD		
insulation voltage for overvoltage category III according to IEC 60664			
 with degree of pollution 3 rated value 	690 V		
type of voltage			
 for monitoring 	AC/DC		
 of the control supply voltage 	AC/DC		
surge voltage resistance rated value	4 kV		
maximum permissible voltage for safe isolation			
 between auxiliary and auxiliary circuit 	300 V		
 between control and auxiliary circuit 	300 V		
protection class IP	IP20		
shock resistance according to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms		
vibration resistance according to IEC 60068-2-6	1 6 Hz: 15 mm, 6 500 Hz: 2g		
mechanical service life (switching cycles) typical	10 000 000		
electrical endurance (switching cycles) at AC-15 at 230 V typical	100 000		
thermal current of the switching element with contacts maximum	5 A		
reference code according to IEC 81346-2	K		
relative repeat accuracy	1 %		
Substance Prohibitance (Date)	05/01/2012		
Product Function			
product function			
 undervoltage detection 	Yes		
 overvoltage detection 	Yes		
 overvoltage detection 1 phase 	Yes		
 overvoltage detection 3 phase 	No		
 overvoltage detection DC 	Yes		
 undervoltage detection 1 phase 	Yes		
 undervoltage detection 3 phases 	No		
undervoltage detection DC	Yes		
 voltage window recognition 1 phase 	Yes		
 voltage window recognition 3 phase 	No		
voltage window recognition DC	Yes		
=			

	V		
adjustable open/closed-circuit current principle	Yes		
• external reset	Yes		
auto-RESET	Yes		
Control circuit/ Control			
control supply voltage at AC			
 at 50 Hz rated value 	17 275 V		
at 60 Hz rated value	17 275 V		
control supply voltage at DC			
• rated value	17 275 V		
operating range factor control supply voltage rated value at DC			
• initial value	1		
• full-scale value	1		
operating range factor control supply voltage rated value at AC at 50 Hz			
• initial value	1		
• full-scale value	1		
operating range factor control supply voltage rated value at AC at 60 Hz			
• initial value	1		
• full-scale value	1		
Measuring circuit			
measurable line frequency	40 500 Hz		
measurable voltage at AC	275 17 V		
measurable voltage at DC	17 275 V		
adjustable response delay time			
when starting	0.1 20 s		
with lower or upper limit violation	0.1 20 s		
accuracy of digital display	+/-1 digit		
relative temperature-related measurement deviation	0.1 %		
Precision			
Precision relative metering precision	5 %		
	5 %		
relative metering precision	5 % 0		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching			
relative metering precision Auxiliary circuit number of NC contacts delayed switching	0		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching	0 0		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching	0 0 1		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit	0 0 1		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5	0 0 1 5 000 1/h		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation design of the electrical isolation	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of CO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation design of the electrical isolation galvanic isolation	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of CO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation design of the electrical isolation • between input and output	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of CO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation • between input and output • between the outputs	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation design of the electrical isolation galvanic isolation • between input and output • between the outputs • between the voltage supply and other circuits	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge		
relative metering precision Auxiliary circuit number of NC contacts delayed switching number of NO contacts delayed switching number of CO contacts delayed switching operating frequency with 3RT2 contactor maximum Main circuit number of poles for main current circuit operational current at 17 V minimum continuous current of the DIAZED fuse link of the output relay Electromagnetic compatibility conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5 field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2 Galvanic isolation design of the electrical isolation galvanic isolation • between input and output • between the outputs • between the voltage supply and other circuits Connections/ Terminals product component removable terminal for auxiliary	0 0 1 5 000 1/h 1 5 mA 4 A 2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge Protective separation Yes Yes No		

type of connectable conductor cross-sections	4 (0.5 4 0) 0 (0.5	0.5	
• solid	1x (0.5 4 mm2), 2x (0.5		
finely stranded with core end processing	1x (0.5 2.5 mm2), 2x (0.5 .	1.5 mm2)	
at AWG cables solid	2x (20 14)		
at AWG cables stranded	2x (20 14)		
connectable conductor cross-section	0.5 4 mm²		
solidfinely stranded with core end processing	0.5 4 IIIII ⁻		
AWG number as coded connectable conductor cross	0.5 2.5 mm		
section • solid	20 14		
stranded	20 14		
tightening torque with screw-type terminals	1.2 0.8 N·m		
nstallation/ mounting/ dimensions	1.2 0.0 IV III		
mounting position	any		
fastening method	snap-on mounting		
height	92 mm		
width	22.5 mm		
depth	91 mm		
required spacing			
with side-by-side mounting			
— forwards	0 mm		
— backwards	0 mm		
— upwards	0 mm		
— downwards	0 mm		
— at the side	0 mm		
 for grounded parts 			
— forwards	0 mm		
— backwards	0 mm		
— upwards	0 mm		
— at the side	0 mm		
— downwards	0 mm		
for live parts			
— forwards	0 mm		
— backwards	0 mm		
— upwards	0 mm		
— at the side	0 mm		
mbient conditions			
installation altitude at height above sea level maximum	2 000 m		
ambient temperature	05 00 00		
during operation	-25 +60 °C		
during storage	-40 +85 °C		
during transport	-40 +85 °C		
ertificates/ approvals			
			Declaration of



Confirmation









Test Certificates Marine / Shipping other Railway

Type Test Certificates/Test Report

Special Test Certificate





Confirmation

Vibration and Shock

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UG4633-1AL30

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UG4633-1AL30

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3UG4633-1AL30

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UG4633-1AL30&lang=en

Characteristic: Derating

https://support.industry.siemens.com/cs/ww/en/ps/3UG4633-1AL30/manual

last modified: 11/17/2021 🖸