## **Technical Information**

PrimeSTACK™

# 2PS18012E44G40113




## **Preliminary data**


## **General information**

#### IGBT Stack for typical voltages of up to 400 $V_{\text{RMS}}$ Rated output current 770 ARMS

- Solar power
  Motor drives
- · High power converter
- · 62mm power module
  · Trenchstop<sup>™</sup> IGBT4

Topology	1/2 B2I
Application	Inverter
Load type	Resistive, inductive
Semiconductor (Inverter Section)	4x FF450R12KE4
DC Link	1.6 mF
Heatsink	Forced air cooled (fan not included)
Implemented sensors	Current, voltage, temperature
Driver signals IGBT	Electrical
Approvals	UL 508C
Sales - name	2PS18012E4FG40113
SP - No.	SP001178324





PrimeSTACK™

2PS18012E44G40113



## **Preliminary data**

## Absolute maximum rated values

Collector-emitter voltage	IGBT; T <sub>vj</sub> = 25°C	V <sub>CES</sub>	1200	V
Repetitive peak reverse voltage	Diode; T <sub>vj</sub> = 25°C	V <sub>RRM</sub>	1200	V
DC link voltage		V <sub>DC</sub>	1000	V
Insulation management	according to installation height of 2000 m	V <sub>line</sub>	500	V <sub>RMS</sub>
Insulation test voltage	according to EN 50178, f = 50 Hz, t = 1 s	VISOL	2.5	kV <sub>RMS</sub>
Repetitive peak collector current inverter section (IGBT)	t <sub>p</sub> = 1 ms	I <sub>CRM2</sub>	2560	A
Repetitive peak forward current inverter section (Diode)	t <sub>p</sub> = 1 ms	I <sub>FRM2</sub>	2440	A
Continuous current inverter section		I <sub>AC2</sub>	820	A <sub>RMS</sub>
Junction temperature	under switching conditions	T <sub>vjop</sub>	150	°C
Switching frequency inverter section	limited due to snubber caps	f <sub>sw2</sub>	3	kHz

Notes

Further maximum ratings are specified in the following dedicated sections

## **Characteristic values**

#### DC Link

			min.	typ.	max.	
Rated voltage		V <sub>DC</sub>		650	1000	V
Over voltage shutdown	within 600 µs			1050		V
Capacitor	1 s, 4 p, rated tol. 10 %	C <sub>DC</sub>		1.6		mF
Maximum ripple current	per device, T <sub>amb</sub> = 55 °C	I <sub>ripple</sub>			49	A <sub>RMS</sub>

Notes

Activ clamping diodes not implemented, max. DC link voltage for short circuit protection 500V Max. DC link voltage under switching conditions 1000V up to 300A (T junction > 25°C)

#### **Inverter Section**

Inverter Section			min.	typ.	max.	
Rated continuous current	$ \begin{array}{l} V_{DC} = 650 \ V, \ V_{AC} = 400 \ V_{RMS}, \ cos(\phi) = 0.85, \\ f_{AC \ sine} = 50 \ Hz, \ f_{sw} = 3000 \ Hz, \ T_{inlet} = 50 ^{\circ}C, \ T_{j} \leq 125 \ ^{\circ}C \end{array} $	I <sub>AC</sub>		770		A <sub>RMS</sub>
Rated continuous current for 150% overload capability	$I_{AC \ 150\%} \text{ = 820 } A_{RMS},  t_{on \ over} \text{ = 60 } s,  T_j \leq 125 \ ^{\circ}C$	I <sub>AC over1</sub>			550	A <sub>RMS</sub>
Rated continuous current for 150% overload capability	$I_{AC~150\%}$ = 820 A <sub>RMS</sub> , t <sub>on over</sub> = 3 s, $T_j \leq 125~^\circ\text{C}$	AC over2			630	ARMS
Over current shutdown	within 15 µs	I <sub>AC OC</sub>		1280		$A_{\text{peak}}$
Power losses	$ \begin{array}{l} I_{AC} = 400 \; A, \; V_{DC} = 650 \; V, \; cos(\phi) = 0.85, \; f_{AC\;sine} = 50 \; Hz, \\ f_{sw} = 3000 \; Hz, \; T_{inlet} = 50 \; ^{\circ}C, \; T_{j} \leq 125 \; ^{\circ}C \end{array} $	P <sub>loss</sub>		5600		W
Notos			•			

Notes

Maximum junction temperature limited to 125°C under all operating conditions

approved by: YZ revision: 2.0	prepared by: OW	date of publication: 2014-11-20
	approved by: YZ	revision: 2.0

PrimeSTACK™

2PS18012E44G40113



## **Preliminary data**

### **Controller interface**

Driver and interface board	ref. to separate Application Note			DR240		
		1	min.	typ.	max.	
Auxiliary voltage		Vaux	18	24	30	V
Auxiliary power requirement	V <sub>aux</sub> = 24 V	Paux			40	W
Digital input level	resistor to GND 10 k $\Omega$ , capacitor to GND 1 nF	V <sub>in low</sub>	0		4	V
		Vin high	11		15	V
Digital output level	open collector, logic low = no fault, max. 15 mA	V <sub>out low</sub>	0		1.5	V
		V <sub>out high</sub>		15		V
Analog current sensor output inverter section	load max 5 mA, @ 770 A <sub>RMS</sub>	VIU ana2 VIV ana2 VIW ana2	6	6.1	6.2	V
Analog DC link voltage sensor output	load max 5 mA, @ 650 V	V <sub>DC ana</sub>	5.4	5.5	5.6	V
Over temperature shutdown inverter section	load max 5 mA, @T <sub>NTC</sub> = 86 °C	VError OT2	10.8	11	11.2	V

#### System data

System data				min.	typ.	max.	
EMC robustness	according to IEC 61800-3 at named	power	V <sub>Burst</sub>		2		kV
interfaces	Interfaces	control	V <sub>Burst</sub>		1		kV
		aux (24V)	V <sub>surge</sub>		1		kV
Storage temperature			T <sub>stor</sub>	-40		80	°C
Operational ambient temperature	PCB, DC link capacitor, bus bar, excludi medium	PCB, DC link capacitor, bus bar, excluding cooling Top amb		-25		60	°C
Cooling air velocity	PCB, DC link capacitor, bus bar, standard atmosphere V <sub>air</sub>		2			m/s	
Humidity	no condensation		Rel. F	0		85	%
Vibration	according to IEC 60721					5	m/s²
Shock	according to IEC 60721				50	m/s <sup>2</sup>	
Protection degree					IP00		
Pollution degree					2		
Dimensions	width x depth x height			284	472	287	mm
Weight					19		kg

System data valid for continuous operation

#### Heatsink air cooled

Heatsink air cooled			min.	typ.	max.	
Air flow	$T_{air}$ = 20 °C, $P_{air}$ = 1013 hPa, dry and dust free, measured at the side of the heat sink according to DIN 41882	ΔV/Δt	500			m³/h
Air pressure drop	at min. air flow	Δp		200		Pa
Air inlet temperature		Tinlet	-30		55	°C

#### Notes

Conditions are standard Infineon characterization for heatsinks.

prepared by: OW date of publication: 2014-11-20 approved by: YZ revision: 2.0

## **Technical Information**

PrimeSTACK™


2PS18012E44G40113



## Preliminary data

Overview of optional components	Unit 1	Inverter Section	Unit 3
Parallel interface board			
Optical interface board			
Voltage sensor		×	
Current sensor		×	
Temperature sensor		×	
Temperature simulation			
DC link capacitors		×	
Data cable for control signals			
Fan			
Collector-emitter Active Clamping			
Snubber capcitors		×	

prepared by: OW	date of publication: 2014-11-20
approved by: YZ	revision: 2.0






# 2PS18012E44G40113


### **Preliminary data**

## **Mechanical drawing**


PrimeSTACK™

**Technical Information** 





#### 



#### Terms & Conditions of usage

The data contained in this product data sheet is exclusively intended for technically trained staff. You and your technical departments will have to evaluate the suitability of the product for the intended application and the completeness of the product data with respect to such application.

This product data sheet is describing the characteristics of this product for which a warranty is granted. Any such warranty is granted exclusively pursuant the terms and conditions of the supply agreement. There will be no guarantee of any kind for the product and its characteristics.

Should you require product information in excess of the data given in this product data sheet or which concerns the specific application of our product, please contact the sales office, which is responsible for you (see www.infineon.com, sales&contact). For those that are specifically interested we may provide application notes.

Due to technical requirements our product may contain dangerous substances. For information on the types in question please contact the sales office, which is responsible for you.

Should you intend to use the Product in aviation applications, in health or live endangering or life support applications, please notify. Please note, that for any such applications we urgently recommend

- to perform joint Risk and Quality Assessments;
- the conclusion of Quality Agreements;
- to establish joint measures of an ongoing product survey, and that we may make delivery depended on the realization of any such measures.

If and to the extent necessary, please forward equivalent notices to your customers.

Changes of this product data sheet are reserved.

#### Safety Instructions

Prior to installation and operation, all safety notices and warnings and all warning signs attached to the equipment have to be carefully read. Make sure that all warning signs remain in a legible condition and that missing or damaged signs are replaced. To installation and operation, all safety notices and warnings and all warning signs attached to the equipment have to be carefully read. Make sure that all warning signs remain in a legible condition and that missing or damaged signs are replaced. Make sure that all warning signs remain in a legible condition and that missing or damaged signs are replaced.

prepared by: OW	date of publication: 2014-11-20
approved by: YZ	revision: 2.0