SIEMENS

Data sheet

SIMATIC IFP1900 V2 PRO, 19 multi-touch display (16:9) with 1920x1080 pixel resolution, PRO variant support arm, for 24 V DC, DisplayPort, can be placed up to 100 m away HDBaseT, USB on the rear side, standard design



Figure similar

| General information | |
|----------------------------------------------------------------------|------------------------------------------|
| Product type designation | IFP1900 V2 PRO |
| Short designation | Flat Panel 19" PRO multi-touch ext. |
| Display | |
| Design of display | TFT widescreen display, LED backlighting |
| Screen diagonal | 18.5 in; 19" |
| Screen diagonal [cm] | 47 cm |
| Display width | 408.96 mm |
| Display height | 230.04 mm |
| On Screen Display (OSD) configuration | No; Adjustable by means of software |
| Number of colors | 16 777 216; 24 bit |
| Viewing angle | 178° x 178° |
| Resolution (pixels) | |
| Image resolution | 1 920 x 1 080 |
| Horizontal image resolution | 1 920 pixel |
| Vertical image resolution | 1 080 pixel |
| Pixel size, horizontal | 0.213 mm |
| Pixel size, vertical | 0.213 mm |
| General features | |
| Brightness/contrast | 350 cd/m² / 1 000:1 |
| non-reflective and tempered mineral glass screen | Yes |
| Detachable from computer unit | 100 m; HDBaseT protocol |
| • Luminance | 350 cd/m² |
| Backlighting | |
| Type of backlighting | LED |
| MTBF backlighting (at 25 °C) | 50 000 h; At 25°C |
| Backlight dimmable | Yes; 0-100 % |
| Control elements | |
| Control elements | multi-touch screen |
| Input device | |
| Integrated mouse cursor control | Yes; Also externally via USB |
| Touch operation | |
| Design as touch screen | Yes; Projective-capacitive |
| Design as multi-touch screen | Yes; Projective-capacitive |
| Monitor keyboard | Yes |
| Installation type/mounting | |
| Design | Support arm mounting |
| Front mounting | No |
| Support arm mounting | Yes |

| 0.1.6 | N. |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Stand mounting | No |
| VESA mounting | Yes; VESA 100 x 100 integrated |
| maximum permitted forward tilt angle from vertical | 45° |
| maximum permitted backward tilt angle from vertical | 45° |
| Supply voltage | |
| Type of supply voltage | DC |
| Rated value (DC) | 24 V; PELV / SELV floating |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |
| Input current | |
| Current consumption (rated value) | 1.2 A |
| Current consumption, max. | 1.5 A |
| Starting current inrush I2t | 0.5 A ² ·s |
| Power loss | |
| Power loss, typ. | 29 W |
| Power loss, max. | 36 W |
| Interfaces | |
| Number of USB interfaces | 2; USB 2.0 type A |
| USB on the rear | Yes; 2x onboard |
| Connection for keyboard/mouse | USB |
| Video interfaces | |
| DisplayPort | Yes; Display port V1.2 |
| Touch interfaces | ,, |
| • USB | Yes |
| Degree and class of protection | |
| IP (at the front) | IP65 |
| IP (rear) | IP65 |
| NEMA (front) | 11 00 |
| Enclosure Type 4 at the front | Yes |
| Enclosure Type 4x at the front Enclosure Type 4x at the front | Yes |
| Enclosure Type 4x at the north | 163 |
| Standards approvals cortificates | |
| Standards, approvals, certificates Certificate of suitability | hazardous zone 2/22: shinhuilding |
| Certificate of suitability | hazardous zone 2/22; shipbuilding |
| Certificate of suitability CE mark | Yes |
| Certificate of suitability CE mark UL approval | Yes Yes |
| Certificate of suitability CE mark UL approval cULus | Yes Yes Yes; Corresponds to UL 508 |
| Certificate of suitability CE mark UL approval cULus FM approval | Yes Yes Yes; Corresponds to UL 508 Available soon |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) | Yes Yes Yes; Corresponds to UL 508 Available soon Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC | Yes Yes Yes; Corresponds to UL 508 Available soon Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22 | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes Yes Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes Yes Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yos No |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Your Care to the state of th |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yos No |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. | Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Relative humidity • Operation, max. Vibrations | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes No 0 °C 45 °C -20 °C 60 °C 95 %; no condensation |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yos No 0 °C 45 °C -20 °C 60 °C 95 %; no condensation |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yos No 0 °C 45 °C -20 °C 60 °C 95 %; no condensation |
| Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas | Yes Yes Yes; Corresponds to UL 508 Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes O°C 45 °C -20 °C 60 °C 95 %; no condensation |

| Mechanics/material | | |
|--------------------------------------|--------------------------------|--|
| Enclosure material (front) | In standard design | |
| Aluminum | Yes | |
| Aluminum casting | Yes | |
| • Glass | Yes; at front | |
| Enclosure material (rear) | aluminum | |
| Dimensions | | |
| Width | 462 mm | |
| Height | 296 mm; Without basic adapter | |
| Depth | 93.7 mm; Without basic adapter | |
| Width of the housing front | 462 mm | |
| Height of housing front | 292 mm | |
| Weights | | |
| Weight (without packaging) | 6.3 kg | |
| Weight (with packaging) | 7 kg | |

last modified: 5/31/2023 🖸