



- NOTES:**
1. DUAL RATED FOR INSULATED COPPER AND ALUMINUM WIRE.
 2. FOR OUTDOOR OR INDOOR INSTALLATION ON ENERGIZED CONDUCTOR (NOT UNDER LOAD).
 3. MOLDED OF GLASS-FILLED NYLON FOR LONG LIFE
 4. EXTRA HARD COPPER TEETH FOR PROPER PENETRATION.
 5. USE AS TAP, SPLICE, OR DEAD END.
 6. NO NEED TO STRIP INSULATION.



CATALOG NUMBER	VOLTS	COND. RANGE		CURRENT RATING		DIMENSIONS (IN)			RECOMM. TORQUE FT. LBS.	BOLT - NUT	NO. OF BOLTS
		RUN	TAP	CU	AL	WIDTH	HEIGHT	LENGTH			
IPC500-250-2	600	500-350	250-4	260	205	2.90	3.75	2.42	60	5/8 - 11/16	1

										CAD FILENAME/LAYERS C41364_00			
										PANDUIT CORP TINLEY PARK, ILLINOIS			
										INSULATION - PIERCING CONNECTOR IPC500-250-2 CUSTOMER DRAWING			
										UNLESS OTHERWISE SPECIFIED, DIMENSIONAL TOLERANCES ARE: (.X) ± (.XXX) ± (.XX) ± ANGLES ±		UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE GIVEN IN INCHES, THIRD ANGLE PROJECTION	
										DRAWN BY CJW MAT'L:		SCALE NONE	
										DATE 11/02		DRAWING NO. C41364	
										CHK'D		DWG SIZE B	
REV	DATE	BY	CHK	DESCRIPTION				ECN	R	CUST	SUP		
00	11/02	CJW		DRAWING RELEASED								SEE NOTE #3	