
CSM D4F DS F 5 5

# **Ultra-Small Safety Limit Switch**

- An incredibly small limit switch with a direct opening mechanism (four-contact construction model).
- High-sensitivity safety limit switch.
- Built-in switches with two- or four-contact construction are available.
- Degree of protection: IP67
- Conforms to EN115-1, EN81-1 and EN81-2. (slow-action models only)
- Certified standards: UL, EN (TÜV), and CCC





For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

# **Model Number Structure**

# **Model Number Legend**

- 1. Built-in Switch
  - 1: 1NC/1NO (slow-action)
  - 2: 2NC (slow-action)
  - 3: 2NC/2NO (slow-action)
  - 4: 4NC (slow-action)
- 2. Actuator
  - 02: Roller plunger (Metal roller)
  - 20: Roller lever

(Metal lever, resin roller)

- 3. Cable Length
  - 1: 1 m
  - 3: 3 m
  - 5: 5 m
- 4. Pull-outing direction of cable
  - R: Horizontal
  - D: Vertical

# Ordering Information

# **List of Models**

#### Safety Limit Switches (with Direct Opening Mechanism)

Consult with your OMRON representative when ordering any models that are not listed in this table.

			Built-in switch							
Actuator	Cable length	Pull-outing direction of cable	1NC/1NO (slow-action)		2NC (slow-action)		2NC/2NO (slow-action)		4NC (slow-action)	
			Model	Direct opening	Model	Direct opening	Model	Direct opening	Model	Direct opening
Dellantaria	1 m	Horizontal	D4F-120-1R		D4F-220-1R		D4F-320-1R		D4F-420-1R	
Roller lever (Metal lever,	1 111	Vertical	D4F-120-1D		D4F-220-1D	$\bigcirc$	D4F-320-1D	$\bigcirc$	D4F-420-1D	$\rightarrow$
resin roller)	3 m	Horizontal	D4F-120-3R		D4F-220-3R		D4F-320-3R		D4F-420-3R	
	3111	Vertical	D4F-120-3D	120-3D D4F-220-3D	D4F-320-3D	$\rightarrow$	D4F-420-3D	$\rightarrow$		
(A)	5 m	Horizontal	D4F-120-5R		D4F-220-5R		D4F-320-5R		D4F-420-5R	
1*1	5 111	Vertical	D4F-120-5D	$\bigcirc$	D4F-220-5D	$\bigcirc$	D4F-320-5D		D4F-420-5D	$\rightarrow$
Roller	1 m	Horizontal	D4F-102-1R		D4F-202-1R		D4F-302-1R		D4F-402-1R	
plunger	1 111	Vertical	D4F-102-1D	$\bigcirc$	D4F-202-1D	<b>D4</b>	D4F-302-1D		D4F-402-1D	$\bigcirc$
(Metal roller)	3 m	Horizontal	D4F-102-3R		D4F-202-3R		D4F-302-3R		D4F-402-3R	
	3 M	Vertical	D4F-102-3D	$\bigcirc$	D4F-202-3D	$\bigcirc$	D4F-302-3D	$\rightarrow$	D4F-402-3D	$\bigcirc$
0	5 m	Horizontal	D4F-102-5R		D4F-202-5R		D4F-302-5R		D4F-402-5R	
$\Delta$	2 111	Vertical	D4F-102-5D	$\bigcirc$	D4F-202-5D		D4F-302-5D	$\rightarrow$	D4F-402-5D	$\bigcirc$

# **Specifications**

# Standards and EC Directives

# Conforms to the following EC Directives:

- Machinery Directive
- Low Voltage Directive
- EN50047
- EN60204-1
- EN ISO 14119
- GS-ET-15

# Certified Standards

Certification body	Standards	File No.
TÜV SÜD	EN60947-5-1 (certified direct opening)	*1
UL *2	UL508 CSA C22.2 No.14	E76675
CQC (CCC) *3	GB/T14048.5	*1

<sup>\*1.</sup> Contact your OMRON sales representative.

# Certified Standard Ratings

TÜV (EN60947-5-1), CCC (GB/T14048.5)

Item	Utilization category	AC-15	DC-13
Rated	operating current (l <sub>e</sub> )	0.75 A	0.27 A
Rated operating voltage (Ue)		240 V	250 V

Note: Use a 10 A fuse type  ${\rm gI}$  or  ${\rm gG}$  that conforms to IEC60269 as a short-circuit protection device.

# UL/CSA (UL508, CSA C22.2 No. 14)

#### C300

Rated	Carry current	Current (A)		Volt-amperes (VA)	
voltage	Carry Current	Make	Break	Make	Break
120 VAC 240 VAC	2.5 A	15 7.5	1.5 0.75	1,800	180

#### Q300

Rated	Carry current	Current (A)		Volt-amperes (VA)	
voltage	Carry Current	Make	Break	Make	Break
125 VDC 250 VDC	2.5 A	0.55 0.27	0.55 0.27	69	69

<sup>\*2.</sup> Certification has been obtained for CSA C22.2 No. 14 under UL.

**<sup>\*3.</sup>** Ask your OMRON representative for information on certified models.


# **Characteristics**

Degree of protection *1		IP67 (EN60947-5-1)				
	Mechanical	10,000,000 times min.				
Durability *2 Electrical		1,000,000 times min. (4 mA resistive load at 24 VDC, 4 circuits) 150,000 times min. (1 A resistive load at 125 VAC, 2 circuits/4 mA resistive load at 24 VDC, 2 circuits) *3				
Operating speed		1 mm/s to 0.5 m/s				
Operating frequency	Mechanical	120 operations/minute				
Operating frequency	Electrical	30 operations/minute				
Contact resistance *5		300 m $\Omega$ max. (with 1 m cable), 500 m $\Omega$ max. (with 3 m cable), 700 m $\Omega$ max. (with 5 m cable)				
Minimum applicable load	d <b>*</b> 4	4 mA resistive load at 24 VDC, 4 circuits (N-level reference value)				
Rated insulation voltage	(Ui)	250 V				
Rated frequency		50/60 Hz				
Protection against electr	ric shock	Class I (with a ground wire)				
Pollution degree (operat	ing environment)	3 (EN60947-5-1)				
	Between terminals of same polarity	2.5 kV				
Impulse withstand voltage (EN60947-5-1)	Between terminals of different polarity	4 kV				
	Between each terminal and ground	4 kV				
Insulation resistance		$100~M\Omega$ min. (at 500 VDC) between terminals of the same polarities, between terminals of different polarities, between current-carrying metal parts and grounds, and between each terminal and non-current carrying metal parts				
Contact gap		$2 \times 2$ mm min.				
Vibration resistance	Malfunction	10 to 55 Hz, 0.75 mm single amplitude				
Shock resistance	Destruction	1,000 m/s² min.				
SHOCK resistance	Malfunction	300 m/s <sup>2</sup> min.				
Conditional short-circuit	current	100 A (EN60947-5-1)				
Conventional free air thermal current (Ith)		2.5 A (EN60947-5-1)				
Ambient operating temperature		-30 to 70°C (with no icing)				
Ambient operating humi	dity	95% max.				
Cable		UL2464 No. 22 AWG, finishing O.D.: 8.3 mm				
Weight		Approx. 190 g (D4F-102-1R, with 1 m cable) Approx. 220 g (D4F-120-1R, with 1 m cable)				

- Note: 1. The above values are initial values.
  - 2. Once the contact is opened or closed with an ordinary load, it cannot be used for a load smaller than that. The contact surface may be rough, which impairs the reliability of contacting.
- **\*1.** The degree of protection shown above is based on the test method specified in EN60947-5-1. Be sure to confirm in advance the sealing performance under the actual operating environment and conditions.
- \*2. Durability values are calculated at an operating temperature of 5 to 35°C, and an operating humidity of 40% to 70%. Contact your OMRON sales representative for more detailed information on other operating environments.
- **\*3.** Do not apply 1 A at 125 VAC to more than two circuits.
- **\*4.** The value will vary depending on factors such as the switching frequency, the ambient environment, and the reliability level. Be sure to confirm correct operation with the actual load before application.
- **\*5.** The contact resistance was measured with 0.1 A at 5 to 8 VDC with a fall-of-potential method.


# Structure and Nomenclature

# Structure



# Direct Opening Mechanism

1NC/1NO Contact (slow-action)



Conforms to EN60947-5-1 Direct Opening ( )

(Only the NC contacts have a direct opening function.) When contact welding occurs, the NC contacts are separated from each other by pushing in the plunger.


#### Contact Form

Model	Contact	Contact form	Operating pattern	Remarks
D4F-1□-□□	1NC/1NO (slow-action)	11 12 33 34	11-12 ON Stroke	Only NC contact 11-12 has a certified direct opening mechanism.  The terminals 11-12 and 33-34 can be used as unlike poles.
D4F-2□-□□	2NC (slow-action)	11	11-12 ON Stroke ———	NC contacts 11-12 and 21-22 have a certified direct opening mechanism.  The terminals 11-12 and 21-22 can be used as unlike poles.
D4F-3□-□□	2NC/2NO (slow-action)	11 12 21 22 33 34 43 44	11-12 21-22 33-34 43-44 ON	NC contacts 11-12 and 21-22 have a certified direct opening mechanism.  The terminals 11-12, 21-22, 33-34 and 43-44 can be used as unlike poles.
D4F-4□-□□	4NC (slow-action)	11 12 12 22 31 32 41 42	11-12 21-22 31-32 41-42 ON	NC contacts 11-12, 21-22, 31-32 and 41-42 have a certified direct opening mechanism.  The terminals 11-12, 21-22, 31-32 and 41-42 can be used as unlike poles.

Note: 1. The terminal numbers are according to EN 50013 and the contact symbols are according to EN 60947-5-1.

Note: 2. Variation occurs in the simultaneity of contact opening/closing operations of 2NC, 2NC/2NO, and 4NC contacts. Check contact operation.

# **Dimensions and Operating Characteristics**



Note: Each dimension has a tolerance of 0.4 mm unless otherwise specified.

(16.7)

UL2464 No. 22 AWG, finishing O.D.: 8.3 mm

## Slow-action (1NC/1NO), (2NC), (2NC/2NO), and (4NC)

(17.6)

- 30

Operating Characteris	Model stics	D4F-□20-□R D4F-□20-□D	D4F-□02-□R D4F-□02-□D
Operating force	OF max. *1	5 N	12 N
Release force	RF min. *2	0.5 N	1.5 N
Pretravel	PT1 (11-12 and 21-22) PT1 (31-32 and 41-42) PT2 *3	6±3° (NC) 9±3° (NC) (12°) (NO)	1 mm max. (NC) 1.3 mm max. (NC) (1.2 mm) (NO)
Overtravel	OT min.	40°	3.2 mm
Operating position	OP (11-12 and 21-22) OP (31-32 and 41-42)		29.4±1 mm 29±1 mm
Total travel	TT <b>*</b> 3	(55°)	(4.5 mm)
<b>Direct opening travel</b>	DOT min. *4	18°	1.8 mm
Direct opening force	DOF min.	20 N	20 N

**Note:** Variation occurs in the simultaneity of contact opening/closing operations of 2NC, 2NC/2NO, and 4NC contacts. Check contact operation.

- \*1. The OF value is the maximum load that opens an NC contact (11-12, 21-22, 31-32, 41-42).
- \*2. The RF value is the minimum load that closes an NC contact (11-12, 21-22, 31-32, 41-42).
- \*3. The PT2 and TT values are reference values.

(42.7)

(7.9)

\$4. The D4F is used in accordance with EN81 and EN115 at a minimum DOT of  $30^{\circ}$  and 2.8 mm.

(16.7)

(17.6)

-30

UL2464 No. 22 AWG, finishing O.D.: 8.3 mm

# **Safety Precautions**

Be sure to read the precautions for All Safety Limit Switches in the website at:http://www.ia.omron.com/.

### Indication and Meaning for Safe Use


Precautions for Safe Use	Supplementary comments on what to do or avoid doing, to use the product safely.
Precautions for Correct Use	Supplementary comments on what to do or avoid doing, to prevent failure to operate, or undesirable effect on product performance.

Precaut	ions	for	Safe	Use

- Do not use more than one D4F side-by-side.
- Do not switch circuits for two or more standard loads (125 VAC,
   1 A). Doing so may adversely affect insulation performance.

### **Handling of Cables**

- Cables cannot be flexed repeatedly.
- The cable is fixed with sealing materials on the bottom of the switch. When excessive force may be imposed on the cable, fasten the cable with a fixing unit at a distance of 50 mm from the bottom of the switch as shown.
- Do not pull or press the cable at an excessive force (50 N max.).
- When bending the cable, secure the cable with more than 45 mm bending radius so as not to cause damage to the insulator or sheath of the cable. Doing so may result in current leakage or burning.



 When wiring, be sure to prevent penetration of a liquid such as water or oil through the cable end.

### **Operating Environment**

 Do not use the Switch submersed in oil or water or in locations continuously subject to splashes of oil or water. Doing so may result in oil or water entering the Switch. (The IP67 degree of protection of the Switch specifies the amount of water penetration after the Switch is submerged in water for a certain period of time.)


#### **Precautions for Correct Use**

The Switch contacts can be used with either standard loads or microloads. Once the contacts have been used to switch a load, however, they cannot be used to switch smaller loads. The contact surfaces will become rough once they have been used and contact reliability for smaller loads may be reduced.

### **Appropriate Tightening Torque**

Be sure to tighten each screw of the D4F properly, otherwise the D4F may soon malfunction


No.	Туре	Appropriate tightening torque
1	Lever mounting screw (M5)	2.4 to 2.8 N·m
2	Body mounting screw (M4)	1.18 to 1.37 N·m



### Mounting

Use two M4 screws and washers to mount the D4F securely. The D4F can be mounted more securely with proper tightening torque.

### Mounting Holes (Unit: mm)



#### **Changing the Lever Angle**


- Unfasten the screw that holds the lever to set the position of the lever at any angle through 360° (in steps of 9°).
- After unfastening the screws that hold the lever, mount the lever the other way (normal side or reverse side). Set an angle of the lever to complete adjustment within a range in which the lever does not touch the switch body.

#### Wiring

#### **Identifying Wires**

Identify wires according to the color (with or without white lines) of the insulation on the wire.

#### Cross section




#### **Core Insulator Colors**

Blue/white, Orange/white, Pink/white, Brown/white, Green/yellow, Brown, Pink, Orange, and Blue Example: Blue/white is a blue insulator with a white line.


#### **Terminal Numbers**

- Identify terminal numbers based on the color (with or without white lines) of the insulation on the wire.
- The safety and auxiliary contacts of D4F models of four-terminal contact construction and those of two-terminal contact construction are described below.
- The safety contacts are direct-opening NC contacts (11-12 and 21-22); they are used for safety circuits, and each of them is indicated with the appropriate mark \_\_\_\_\_.
- Auxiliary contacts are used to check (to monitor) the operating state of the switch, which are equivalent to NO contacts (33-34 and 43-44) or NC contacts (31-32 and 41-42).
- The NC contacts 31-32 and 41-42 of auxiliary contacts (orange or pink) can be used as safety contacts.


## <1NC/1NO>




#### <2NC>



#### <2NC/2NO>



#### <4NC>




### Note: Safety Contacts:

The safety contacts are direct opening contacts certified by EN and each of them is indicated with the mark  $\bigodot$  .


• Cut the dummy core insulator and all unused wires at the end of the external insulation sheath when wiring the cable.

### Operating

 To set the plunger stroke correctly, press-fit the plunger until the top of the pushing surface comes between two grooves on the plunger.




• To set the roller lever stroke correctly, push the dog and cam until the lance point comes within the range of the convex part that is the correct setting position.



#### **Others**

 Actuating the switch from an angle other than 90 degrees to the switch face may deform or damage the actuator, or deform or damage the rotary spindle, so make sure that the dog is straight.



- Do not remove the head. Otherwise, a failure may occur.
- To avoid telegraphing, take the following precautions.
  - 1. Modify the rear end of the dog to an angle of 15° to 30° as shown below or to a secondary-degree curve.



Modify the circuit so as not to detect the wrong operating signals.

### Terms and Conditions Agreement

#### Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

#### Warranties.

- (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.
- (b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE

PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See <a href="http://www.omron.com/global/">http://www.omron.com/global/</a> or contact your Omron representative for published information.

#### Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

#### Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

#### Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

#### Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

#### Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions.
Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

2022.11

In the interest of product improvement, specifications are subject to change without notice.