

NOTES:


- ① MAT'L: COPPER (STOCK TKN. $\frac{.031}{.79}$)
- PLATING: ELECTRO TIN (.0003 MIN)
- ② TIN-PLATED BRASS FERRULE

STUD SIZES: ($\pm .005$)

- 02 = .094
- 04 = .119
- 06 = .146
- 08 = .173
- 10 = .198
- 14 = .265
- 56 = .328
- 38 = .390

"UL" LISTING #E32244
 "CSA" LISTING #18689

WIRE SIZE: 16 - 14 AWG
 10 - 2.5 MM²



ALL DIMENSIONS = $\frac{\text{INCHES}}{\text{MM}}$ (MWID) DENOTES MAXIMUM WIRE INSULATION DIAMETER

PART NUMBER	"W" ±.010	"C" MIN.	"L" MAX.	REFERENCE		SCALE:	DATE	TITLE:	DWG. NO.
				SCALE:	DATE				
B-418-	$\frac{.534}{13.56}$	$\frac{.554}{14.07}$	$\frac{1.259}{31.98}$			NTS	11-16-84	RING TONGUE TERMINAL VIBRAKRIMP 400 SERIES	A
B-423-	$\frac{.250}{6.35}$	$\frac{.209}{5.31}$	$\frac{.783}{19.89}$			NTS	11-30-84		A
B-425-	$\frac{.467}{11.86}$	$\frac{.388}{9.86}$	$\frac{1.060}{26.92}$			NTS			A
B-437-	$\frac{.312}{7.92}$	$\frac{.285}{7.24}$	$\frac{.874}{22.20}$			NTS			A
B-439-	$\frac{.342}{8.69}$	$\frac{.310}{7.87}$	$\frac{.919}{23.24}$			NTS			A
DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED FRAC. DEC. ANG.									
DRAWN BY: JJ CHKD. BY: GZ APPRD. BY:									



CUSTOMER DWG