## **SIEMENS**

Data sheet 3TY7561-1S

	Auxiliary switch block, 2 NO + 2 NC, for 3TL8 with screw to	erminals
product category	Auxiliary switch	
product designation	Double block auxiliary switch left	
suitability for use	Contactor relay and power contactor	
eneral technical data		
insulation voltage with degree of pollution 3 at AC rated value	690 V	
surge voltage resistance rated value	6 kV	
protection class IP on the front	IP20	
mechanical service life (operating cycles) typical	10 000 000	
Substance Prohibitance (Date)	05/01/2012	
number of NC contacts for auxiliary contacts		
<ul> <li>instantaneous contact</li> </ul>	2	
<ul> <li>lagging switching</li> </ul>	0	
number of NO contacts for auxiliary contacts		
• instantaneous contact	2	
leading contact	0	
number of CO contacts of auxiliary contacts instantaneous contact	0	
operational current of auxiliary contacts at DC-12		
• at 24 V	10 A	
• at 110 V	3.2 A	
• at 220 V	0.9 A	
operational current of auxiliary contacts at DC-13		
• at 24 V	0.3 A	
• at 48 V	0.3 A	
• at 60 V	0.3 A	
mbient conditions		
ambient temperature		
during operation	-25 +55 °C	
during storage	-55 +80 °C	
nstallation/ mounting/ dimensions		
fastening method	snap-on mounting	
height	70 mm	
width	24 mm	
depth	51.5 mm	
connections/ Terminals		
type of electrical connection for auxiliary and control circuit	screw-type terminals	
connectable conductor cross-section for auxiliary contacts	co.cu. type teaic	
solid or stranded	0.5 2.5 mm²	
finely stranded with core end processing	0.5 2.5 mm²	
type of connectable conductor cross-sections	V.O 2.0 Hilli	
• for auxiliary contacts		
— solid or stranded	2x (0,5 1,0 mm²), 2x (1,0 2,5 mm²)	
— finely stranded with core end processing	2x (0.5 1,0 mm²), 2x (1,0 2,5 mm²)	
Innery stranged with core end processing     for AWG cables for auxiliary contacts	2x (0.5 1.0 min-), 2x (0.75 2.5 min-) 2x (18 12)	
AWG number as coded connectable conductor cross section for auxiliary contacts	2x (18 12) 18 12	
pprovals Certificates		
		Declaration of Co
General Product Approval		formity



Confirmation



EAC



Declaration of Conformity

**Test Certificates** 

other



Special Test Certificate

Confirmation

## **Further information**

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

<u>KC</u>

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3TY7561-1S

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3TY7561-1S

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3TY7561-1S

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3TY7561-1S&lang=en

12/23/2020	
	12/23/2020