## **DATAFORTH**<sup>®</sup>

# **8B43** DC LVDT Input Modules

### Description

8B modules are an optimal solution for monitoring real-world process signals and providing high-level signals to a data acquisition system. Each 8B43 module isolates, filters, and amplifies a voltage input signal and provides an analog voltage output (Figure 1).

The 8B43 can interface to transducers that will operate on a 10V excitation voltage and up to 30mA excitation current.

Signal filtering is accomplished with a 5-pole filter optimized for time and frequency response which provides 100dB per decade of normal-mode rejection above 1kHz. One pole of this filter is on the field side of the isolation barrier for anti-aliasing, and the other four are on the system side.

A special input circuit on the 8B43 modules provides protection against accidental connection of power-line voltages up to 240VAC. Clamp circuits on the I/O and power terminals protect against harmful transients.

Isolation is provided by transformer coupling to suppress transmission of common mode spikes or surges. The module is powered from +5VDC,  $\pm5$ %.

The modules are designed for installation in Class I, Division 2 hazardous locations and have a high level of immunity to environmental noise.

#### **Features**

- Interfaces to DC Linear Voltage Displacement Transducers
- High-Level Voltage Outputs
- 1500Vrms Isolation
- ANSI/IEEE C37.90.1 Transient Protection
- Input Protection to 240VAC Continuous
- 100dB CMR
- 1kHz Signal Bandwidth
- ±0.05% Accuracy
- ±0.02% Linearity
- · Low Drift with Ambient Temperature
- · C-UL-US Listed
- CE Compliant
- ATEX Compliance Pending
- Mix and Match Module Types on Backpanel




Figure 1: 8B43 Blok Diagram

126

#### For information call 800-444-7644

#### **Specifications** Typical\* at T<sub>A</sub> = +25°C and +5VDC power

	Α '
Module	8B43
Input Range Input Bias Current Input Resistance Normal Power Off Overload Input Protection Continuous <sup>(1)</sup>	±1V to ±5V ±0.05nA 2MΩ (minimum) 2MΩ (minimum) 2MΩ (minimum) 240VAC
Transient	ANSI/IEEE C37.90.1
Excitation Voltage Current Load Regulation Stability Protection	+10V ±5mV 5mA min, 30mA max 15ppm/mA 50ppm/°C 120VAC
CMV, Input to Output Transient, Input to Output CMR (50Hz or 60Hz) NMR (-3dB at 1kHz)	1500Vrms max ANSI/IEEE C37.90.1 100dB 100dB per Decade above 1kHz
Accuracy <sup>(2)</sup> Linearity Stability Offset Gain Noise Output, 100kHz Bandwidth, –3dB Response Time, 90% Span	±0.05% Span ±0.02% Span ±25ppm/°C ±100ppm/°C 500µVrms 1kHz 550µs
Output Range Output Protection Transient	See Ordering Information Continuous Short to Ground ANSI/IEEE C37.90.1
Power Supply Voltage Power Supply Current Power Supply Sensitivity	+5VDC ±5% 160mA Full Exc. Load ±100ppm/%
Mechanical Dimensions (h)(w)(d)	1.11" x 1.65" x 0.40" (28.1mm x 41.9mm x 10.2mm)
Environmental Operating Temp. Range Storage Temp. Range Relative Humidity Emissions EN61000-6-4 Radiated, Conducted Immunity EN61000-6-2 RF ESD,EFT	-40°C to +85°C -40°C to +85°C 0 to 95% Noncondensing ISM, Group 1 Class A ISM, Group 1 Performance A ±0.5% Span Error Performance B

NOTES:

\*Contact factory or your local Dataforth sales office for maximum values.
(1) 240VAC between +Input terminal and –Input, +EXC, or –EXC terminals.
120VAC between –Input and +EXC or –EXC terminals.
120VAC between +EXC and –EXC terminals.
(2) Includes linearity, hysteresis and repeatability.

#### **Ordering Information**

Model	Input Range	Output Range
8B43-01	-1V to +1V	-5V to +5V
8B43-02	-2V to +2V	-5V to +5V
8B43-03	-3V to +3V	-5V to +5V
8B43-04	-4V to +4V	-5V to +5V
8B43-05	-5V to +5V	-5V to +5V
8B43-11	-1V to +1V	0V to +5V
8B43-12	-2V to +2V	0V to +5V
8B43-13	-3V to +3V	0V to +5V
8B43-14	-4V to +4V	0V to +5V
8B43-15	-5V to +5V	0V to +5V

#### Installation Notes:

- 1.) This Equipment is Suitable for Use in Class I, Division 2, Groups A, B,C, D, or Non-Hazardous Locations Only.
- 2.) WARNING Explosion Hazard Substitution of Any Components May Impair Suitability for Class I, Division 2.
- 3.) WARNING Explosion Hazard Do Not Disconnect Equipment Unless Power Has Been Switched Off or The Area is Known to be Non-Hazardous.

8B