SIEMENS

Data sheet



Enclosure for command devices, 22 mm, round, Enclosure material plastic, Enclosure top part yellow, 1 control point plastic, Control point in center, A=EMERGENCY STOP mushroom pushbutton red, 40 mm, with RONIS lock SB30, key-operated release, 1 NC, 1NO, screw terminal, floor mounting, 1xM20 each on top and bottom

Figure similar

product brand name

product brand name	SIRIUS ACT
product designation	Enclosures
product type designation	3SU1
equipment of commanding and signaling device	A = EMERGENCY STOP mushroom pushbutton, 40 mm, with positive latching acc. to ISO 13850 and key-operated release
manufacturer's article number	
 of supplied contact module 	A1 = 3SU1400-2AA10-1CA0
 of supplied contact module at the command point A 1 	3SU1400-2AA10-1CA0
 of supplied contact module at the command point A 2 	3SU1400-2AA10-1BA0
 of supplied LED module 	A1 = 3SU1400-2AA10-1BA0
 of the supplied holder 	A = 3SU1500-0AA10-0AA0
 of the supplied holder at the command point A 	3SU1500-0AA10-0AA0
 of the supplied actuator 	A = 3SU1000-1HF20-0AA0
 of the supplied actuator at the command point A 	3SU1000-1HF20-0AA0
 of supplied empty enclosure 	3SU1801-0AA00-0AA2
Enclosure	
design of the housing	Command point in center
shape of the enclosure front	Square
material of the enclosure	plastic
number of command points	1
product component	
 EMERGENCY STOP device 	Yes
protective collar	No
color of the enclosure top part	yellow
delivery state	
• as a kit	No
pre-wired on strip terminal	No
fastening method of the enclosure	Vertical
Actuator	
design of the actuating element	EMERGENCY STOP mushroom pushbutton
suitability for use EMERGENCY OFF switch	Yes
product feature lockout	No
product extension optional light source	No
color of the actuating element	red
material of the actuating element	plastic
shape of the actuating element	round
number of contact modules	2
type of unlocking device	A = key-operated release
Front ring	

SIRIUS ACT

design of the front ring Holder material of the holder Display number of LED modules General technical data	Standard
material of the holder Display number of LED modules	Otaridard
Display number of LED modules	
number of LED modules	Plastic
number of LED modules	
1 11 1	0
product function	
positive opening	Yes
EMERGENCY OFF function	Yes
EMERGENCY STOP function	Yes
protection class IP	IP66, IP67, IP69(IP69K)
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12K, 13
shock resistance	,, =, =, -, -, -,,
according to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms
for railway applications according to EN 61373	Category 1, Class B
vibration resistance	
• according to IEC 60068-2-6	10 500 Hz: 5g
• for railway applications according to EN 61373	Category 1, Class B
reference code according to IEC 81346-2	S
continuous current of the C characteristic MCB	10 A; for a short-circuit current smaller than 400 A
continuous current of the quick DIAZED fuse link	10 A
continuous current of the DIAZED fuse link gG	10 A
Substance Prohibitance (Date)	10/01/2014
operating voltage	10.0 0.2011
• at AC	
— at 50 Hz rated value	5 500 V
— at 60 Hz rated value	5 500 V
at DC rated value	5 500 V
Communication/ Protocol	0 000 V
design of the interface for communication	without
Auxiliary circuit	William
design of the contact of auxiliary contacts	Silver alloy
number of NC contacts for auxiliary contacts	1
number of NO contacts for auxiliary contacts	1
Connections/ Terminals	
type of electrical connection of modules and accessories	Screw type terminal
type of electrical connection on enclosure	Screw-type terminal Cable routing above and below, both 1 x M20
tightening torque of the screws in the bracket	1 1.2 N·m
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m
tightening torque with screw-type terminals	0.8 0.9 N·m
Ambient conditions	0.0 0.0 IV III
ambient temperature	25 ±70 °C
 during operation 	-25 +70 °C -40 +80 °C
• during storage	
during storage anyironmental extensive during operation according to IEC	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)
during storage environmental category during operation according to IEC 60721	. ,
environmental category during operation according to IEC	
environmental category during operation according to IEC 60721	Floor mounting
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions	Floor mounting 85 mm
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories	
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories height	85 mm
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories height width	85 mm 85 mm
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories height width depth	85 mm 85 mm 109 mm
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories height width depth shape of the installation opening Accessories	85 mm 85 mm 109 mm round
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories height width depth shape of the installation opening Accessories number of labels	85 mm 85 mm 109 mm round
environmental category during operation according to IEC 60721 Installation/ mounting/ dimensions fastening method of modules and accessories height width depth shape of the installation opening Accessories	85 mm 85 mm 109 mm round



Confirmation









Declaration of Conformity

Test Certificates

Marine / Shipping





Type Test Certificates/Test Report







Marine / Shipping

other

Environment



Confirmation

Environmental Confirmations

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1801-0NN00-2AA2

Cax online generator

 $\underline{\text{http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3SU1801-0NN00-2AA2}$


 ${\bf Service \& Support \ (Manuals, \ Certificates, \ Characteristics, \ FAQs, ...)}$


https://support.industry.siemens.com/cs/ww/en/ps/3SU1801-0NN00-2AA2

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SU1801-0NN00-2AA2&lang=en







last modified: 1/26/2022 🖸