

Cat. No. Z132-E1-02

F150-2

Vision Sensor

**Manual 1:
SETUP MANUAL**

OMRON®

F150-2

Vision Sensor


Setup Manual


Revised May 2004


Notice:


OMRON products are manufactured for use according to proper procedures by a qualified operator and only for the purposes described in this manual.

The following conventions are used to indicate and classify precautions in this manual. Always heed the information provided with them. Failure to heed precautions can result in injury to people or damage to property.

 **DANGER** Indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury.

 **WARNING** Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.

 **Caution** Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury, or property damage.

	High Temperatures Indicates particular circumstances which, if not avoided, could result in heat burns.
---	---

Visual Aids

The following headings will help you locate different types of information.

Note Indicates information of particular interest for efficient and convenient operation of the product.

→ Indicates pages where additional information can be found.

1 Indicates a procedure. The step numbers in the procedure correspond to the numbers in any related illustrations.

© OMRON, 1999

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form, or by any means, mechanical, electronic, photocopying, recording, or otherwise, without the prior written permission of OMRON.

No patent liability is assumed with respect to the use of the information contained herein. Moreover, because OMRON is constantly striving to improve its high-quality products, the information contained in this manual is subject to change without notice. Every precaution has been taken in the preparation of this manual. Nevertheless, OMRON assumes no responsibility for errors or omissions. Neither is any liability assumed for damages resulting from the use of the information contained in this publication.

Terms and Conditions of Sale

- Offer, Acceptance.** These terms and conditions (these "Terms") are deemed part of all quotes, agreements, purchase orders, acknowledgments, price lists, catalogs, manuals, brochures, and other documents, whether electronic or in writing, relating to the sale of products or services (collectively, the "Products") by Omron Electronics LLC and its subsidiary companies ("Omron"). Omron objects to any terms or conditions proposed in Buyer's purchase order or other documents which are inconsistent with, or in addition to, these Terms.
- Prices, Payment Terms.** All prices stated are current, subject to change without notice by Omron. Omron reserves the right to increase or decrease prices on any unshipped portions of outstanding orders. Payments for Products are due net 30 days unless otherwise stated in the invoice.
- Discounts.** Cash discounts, if any, will apply only on the net amount of invoices sent to Buyer after deducting transportation charges, taxes and duties, and will be allowed only if (i) the invoice is paid according to Omron's payment terms and (ii) Buyer has no past due amounts.
- Interest.** Omron, at its option, may charge Buyer 1-1/2% interest per month or the maximum legal rate, whichever is less, on any balance not paid within the stated terms.
- Orders.** Omron will accept no order less than \$200 net billing.
- Governmental Approvals.** Buyer shall be responsible for, and shall bear all costs involved in, obtaining any government approvals required for the importation or sale of the Product.
- Taxes.** All taxes, duties and other governmental charges (other than general real property and income taxes), including any interest or penalties thereon, imposed directly or indirectly on Omron or required to be collected directly or indirectly by Omron for the manufacture, production, sale, delivery, importation, consumption or use of the Products sold hereunder (including customs duties and sales, excise, use, turnover and license taxes) shall be charged to and remitted by Buyer to Omron.
- Financial.** If the financial position of Buyer at any time becomes unsatisfactory to Omron, Omron reserves the right to stop shipments or require satisfactory security or payment in advance. If Buyer fails to make payment or otherwise comply with these Terms or any related agreement, Omron may (without liability and in addition to other remedies) cancel any unshipped portion of Products sold hereunder and stop any Product in transit. Buyer pays all amounts, including amounts payable hereunder, whether or not then due which are owing to it by Buyer. Buyer shall in any event remain liable for all unpaid accounts.
- Cancellation, Etc.** Orders are not subject to rescheduling or cancellation unless Buyer indemnifies Omron against all related costs or expenses.
- Force Majeure.** Omron shall not be liable for any delay or failure in delivery resulting from causes beyond its control, including earthquakes, fires, floods, strikes or other labor disputes, shortage of labor or materials, accidents to machinery, acts of sabotage, riots, delay in or lack of transportation or the requirements of any government authority.
- Shipping, Delivery.** Unless otherwise expressly agreed in writing by Omron:
 - Shipments shall be by a carrier selected by Omron; Omron will not drop ship except in "break down" situations.
 - Such carrier shall act as the agent of Buyer and delivery to such carrier shall constitute delivery to Buyer;
 - All sales and shipments of Products shall be FOB shipping point (unless otherwise stated in writing by Omron), at which point title and risk of loss shall pass from Omron to Buyer; provided that Omron shall retain a security interest in the Products until the full purchase price is paid;
 - Delivery and shipping dates are estimates only; and
 - Omron will package Products as it deems proper for protection against normal handling and extra charges apply to special conditions.
- Claims.** Any claim by Buyer against Omron for shortage or damage to the Products occurring before delivery to the carrier must be presented in writing to Omron within 30 days of receipt of shipment and include the original transportation bill signed by the carrier noting that the carrier received the Products from Omron in the condition claimed.
- Warranties.** (a) **Exclusive Warranty.** Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied. (b) **Limitations.** OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY,

- ITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) **Buyer Remedy.** Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped) with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repair or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability of the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty. See <http://oeweb.omron.com> or contact your Omron representative for published information.
- Limitation on Liability.** Etc. OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY. Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.
 - Indemnities.** Buyer shall indemnify and hold harmless Omron Companies and their employees from and against all liabilities, losses, claims, costs and expenses (including attorney's fees and expenses) related to any claim, investigation, litigation or proceeding (whether or not Omron is a party) which arises or is alleged to arise from Buyer's acts or omissions under these Terms or in any way with respect to the Products. Without limiting the foregoing, Buyer (at its own expense) shall indemnify and hold harmless Omron and defend or settle any action brought against such Companies to the extent based on a claim that any Product made to Buyer specifications infringed intellectual property rights of another party.
 - Property, Confidentiality.** Any intellectual property in the Products is the exclusive property of Omron Companies and Buyer shall not attempt to duplicate it in any way without the written permission of Omron. Notwithstanding any charges to Buyer for engineering or tooling, all engineering and tooling shall remain the exclusive property of Omron. All information and materials supplied by Omron to Buyer relating to the Products are confidential and proprietary, and Buyer shall limit distribution thereof to its trusted employees and strictly prevent disclosure to any third party.
 - Export Controls.** Buyer shall comply with all applicable laws, regulations and licenses regarding (i) export of products or information; (iii) sale of products to "forbidden" or other proscribed persons; and (ii) disclosure to non-citizens of regulated technology or information.
 - Miscellaneous.** (a) **Waiver.** No failure or delay by Omron in exercising any right and no course of dealing between Buyer and Omron shall operate as a waiver of rights by Omron. (b) **Assignment.** Buyer may not assign its rights hereunder without Omron's written consent. (c) **Law.** These Terms are governed by the law of the jurisdiction of the home office of the Omron company from which Buyer is purchasing the Products (without regard to conflict of law principles). (d) **Amendment.** These Terms constitute the entire agreement between Buyer and Omron relating to the Products, and no provision may be changed or waived unless in writing signed by the parties. (e) **Severability.** If any provision hereof is rendered ineffective or invalid, such provision shall not invalidate any other provision. (f) **Setoff.** Buyer shall have no right to set off any amounts against the amount owing in respect of this invoice. (g) **Definitions.** As used herein, "including" means "including without limitation"; and "Omron Companies" (or similar words) mean Omron Corporation and any direct or indirect subsidiary or affiliate thereof.

Certain Precautions on Specifications and Use

- Suitability of Use.** Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases but the following is a non-exhaustive list of applications for which particular attention must be given:
 - Outdoor use, using involving potential chemical contamination or electrical interference, or conditions or uses not described in this document.
 - Use in consumer products or any use in significant quantities.
 - Energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
 - Systems, machinery and equipment used in hazardous or high risk life or property. Please know and observe all prohibitions of use applicable to this Product.

- ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.
- Performance Data.** Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.
 - Performance Data.** Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.
 - Change in Specifications.** Product specifications and accessories may be changed or improved without notice and for other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron representative at any time to confirm actual specifications of purchased Product.
 - Errors and Omissions.** Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO

TABLE OF CONTENTS

PRECAUTIONS	xi
1 Safety Precautions	xii
2 General Precautions	xiii
SECTION 1	
Before Installing	1
1-1 Installation Precautions	2
1-2 Confirming Package Contents	5
1-3 Product Availability	5
SECTION 2	
Product Introduction	7
2-1 Overview of F150 Application	8
2-2 Component Names and Functions	9
2-3 Connections	12
2-4 Power Supply and Ground	13
2-5 Cameras with Lights	15
2-6 CCTV Lens	17
2-7 Lighting	20
2-8 Mounting the Controller	23
SECTION 3	
Terminal Blocks	25
3-1 Terminal Block Application	26
3-2 Crimp Terminals and Cables	26
3-3 Specifications	27
3-4 Terminals	28
SECTION 4	
RS-232C Connection	31
4-1 RS-232C Port Application	32
4-2 Connector	32
4-3 Wiring	33
4-4 Connection	34
SECTION 5	
CompoBus/D Connections	35
5-1 Overview	36
5-2 Communications Specifications	40
5-3 DIP Switch Settings	41
5-4 Connector Pin Allocation	43
5-5 LED Indicators	44
5-6 Multi-vendor Applications	44

TABLE OF CONTENTS

SECTION 6		
Troubleshooting		51
6-1 Connection Errors		52
6-2 Errors during Menu Operation		52
6-3 Terminal Block Errors		52
6-4 RS-232C Communications Errors		53
6-5 LED Indicators		54
SECTION 7		
Maintenance		55
7-1 Maintenance Parts and Replacement		56
7-2 Regular Inspections		57
SECTION 8		
Specifications		59
8-1 F150 Vision Mate Controller		60
8-2 K150-KP Console		62
8-3 Cameras		63
8-4 F150-LE20/50 Lens		65
8-5 F150-LT10A Light		65
8-6 Cables		66
8-7 F300-M09 Video Monitor		67
8-8 LCD Monitor		68
Revision History		71

About this Manual:

This manual describes the hardware for the F150 Vision Sensor and how to install the components, and it includes the sections described below. This is one of three manuals used to operate the F150. Refer to the following table for the contents of each manual.

Manual	Contents	Cat. No.
1: Setup Manual	Provides information on system hardware and installation. Be sure to read this manual first.	Z132
2: Auto Menu Operation Manual	Describes operation of the F150 using the Auto Menu. The Auto Menu enables the simplest operation based on registered images of acceptable and unacceptable products.	Z133
3: Expert Menu Operation Manual	Describes operation of the F150 using the Expert Menu. The Expert Menu enables application of all F150 capabilities, including setting region images and criteria.	Z134

Please read the above manuals carefully and be sure you understand the information provided before attempting to install or operate the F150.

Section 1 Before Installing describes the precautions that must be taken when installing and operating the F150 Vision Sensor.

Section 2 Product Introduction provides an overview of F150 application and describes the wiring, Cameras, optical lenses, lighting modes, and light guides used in the F150 System. It also describes how to mount the Vision Mate Controller to DIN Track or to a flat surface.

Section 3 Terminal Blocks describes how to connect the terminal blocks.

Section 4 RS-232C Connection describes how to connect the RS-232C port.

Section 5 CompoBus/D Connections describes how to connect the F150-C10E-2-DRT Vision Sensor as a CompoBus/D Slave and provides information such as connector pin allocations, node number settings, and baud rate settings.

Section 6 Troubleshooting lists the errors that may occur, along with their probable causes and remedies.

Section 7 Maintenance provides information on maintenance and inspection.

Section 8 Specifications provides the specifications of the F150 components.



WARNING

Failure to read and understand the information provided in this manual may result in personal injury or death, damage to the product, or product failure. Please read each section in its entirety and be sure you understand the information provided in the section and related sections before attempting any of the procedures or operations given.


PRECAUTIONS

This section provides general precautions for using the F150 Vision Sensor.


The information contained in this section is important for the safe and reliable application of the F150 Vision Sensor. You must read this section and understand the information contained before attempting to set up or operate a F150 Vision Sensor.


1 Safety Precautions	xii
2 General Precautions	xiii


1 Safety Precautions


 **Caution** Do not touch fluorescent or halogen lights while the power is ON or immediately after the power is turned OFF. These lights generate heat and can cause burns.





 **Caution** Cover the terminal blocks with the Terminal Block Protection Covers.


 **Caution** Use DC power supplies with safe extra low-voltage circuits on the secondary side for the main F150 power supply and power supplies for the terminal blocks.


 **Caution** Do not use the F150 in environments with flammable or explosive gases.


 **Caution** Install the F150 away from high-voltage equipment or motors to ensure safety during operation and maintenance.


 **Caution** Use the power supply cables and crimp terminals of specified sizes.


 **Caution** Use at the power supply voltages specified in this manual.

 **Caution** Be sure to securely tighten the screws when mounting F150 components.

 **Caution** Do not dismantle, repair or modify any F150 components.

 **Caution** Dispose of F150 components as industrial waste.

 **Caution** To prevent damage from static electricity, use a wrist strap or another device for preventing electrostatic charges when touching terminals or connector signal lines.

 **Caution** Do not turn OFF the power while a message is being displayed indicating that processing is being performed. Data in memory will be destroyed, and the F150 may not operate correctly the next time it is started.

2 General Precautions

The user must operate the product according to the performance specifications described in the operation manuals.

Before using the product under conditions which are not described in the manual or applying the product to nuclear control systems, railroad systems, aviation systems, vehicles, combustion systems, medical equipment, amusement machines, safety equipment, and other systems, machines, and equipment that may have a serious influence on lives and property if used improperly, consult your OMRON representative.

Make sure that the ratings and performance characteristics of the product are sufficient for the systems, machines, and equipment, and be sure to provide the systems, machines, and equipment with double safety mechanisms.

SECTION 1

Before Installing

This section describes the precautions that must be taken when installing and operating the F150 Vision Sensor.

- 1-1 Installation Precautions 2
 - 1-1-1 F150 Components 2
 - 1-1-2 Installation Site 2
 - 1-1-3 Installation 2
 - 1-1-4 Cables 4
 - 1-1-5 Camera 4
 - 1-1-6 Video Monitor 5
- 1-2 Confirming Package Contents 5
- 1-3 Product Availability 5

1-1 Installation Precautions

The F150 is highly reliable and resistant to most environmental factors. The following guidelines, however, must be followed to ensure reliability and optimum use of the F150.

1-1-1 F150 Components

Be sure to use the Camera, Camera Cable, and Console designed for the F150.

- 1 F150-S1 Camera
- 2 F150-VS Camera Cable
- 3 F150-KP Console

1-1-2 Installation Site

Do not install the F150 in locations subject to the following conditions:


- 1 Ambient temperatures outside of 0 to 40°C for the F300-M09 Video Monitor (recommended monitor) or outside of 0 to 50°C for all other F150 components
- 2 Condensation due to rapid temperature fluctuations
- 3 Relative humidities outside 35% to 85%
- 4 Corrosive or flammable gases
- 5 Dust, salt, or iron particles
- 6 Direct vibration or shock
- 7 Direct sunlight
- 8 Water, oil, or chemical fumes or spray

1-1-3 Installation

Orientation of Controller


To improve heat dissipation, install the Controller in the following orientation only:

CORRECT




Do not install the Controller in the orientations shown in the following diagram.

INCORRECT



Ambient Temperature

- 1 Maintain a minimum clearance of 50 mm above and below F150 components to improve air circulation.
- 2 Do not install F150 components immediately above strong heat sources, such as heaters, transformers, or large-capacity resistors.
- 3 Do not let the ambient operating temperature exceed 50°C.
- 4 Provide a forced-air fan or air conditioning if the ambient temperature might exceed 50°C.




Noise Resistance

Use the following measures to help increase noise resistance.

- 1 Do not install F150 components in a cabinet containing high-voltage equipment.

- 2 Do not install the F150 components within 200 mm of power cables.



F150-C10E-2-DRT (CompoBus/D Model)

- 1 Since the product is defined as built-in type, install the product inside the control panel.
- 2 Do not apply external forces exceeding 50 N to CompoBus/D connectors. When wiring communications cables, remove the connectors from the F150.
- 3 Before setting the DIP switch or connecting cables, turn OFF the Programmable Controller, F150, and the communications power supply.
- 4 Observe the following precautions when wiring communications cables.
 - a) Separate communications cables from power lines or high-tension lines.
 - b) Do not bend communications cables.
 - c) Do not pull on communications cables with excessive force.
 - d) Do not place heavy objects on communications cables.
 - e) Be sure to route communications cables within ducts.

1-1-4 Cables

Always turn OFF the power before connecting or disconnecting cables.

1-1-5 Camera

The Camera's case is connected to the 0V line in the internal circuits. Heed the following precautions to prevent noise interference.

- 1 Do not ground the Camera.
- 2 Do not remove the base attached to the Camera.

- 3 Do not remove the core attached to the F150-VS Camera Cable.

1-1-6 Video Monitor

(When using the recommended F300-M09)

Heed the following precautions to prevent noise interference if the video monitor case is metallic, because it is connected to the 0V line in the internal circuits.

- 1 Do not ground the video monitor.
- 2 Do not ground the metallic part of the connector.
- 3 Secure the video monitor with plastic screws if it is being mounted to a metallic surface.

1-2 Confirming Package Contents

Check the contents of the package as soon as you receive the F150. Contact the nearest OMRON representative if any of the following items are missing.

F150-C10E-2 F150-C15E-2

- | | |
|--------------------------------|---|
| 1 F150 Vision Mate Controller | 1 |
| 2 Setup Manual (this manual) | 1 |
| 3 Auto Menu Operation Manual | 1 |
| 4 Expert Menu Operation Manual | 1 |

F150-C10E-2-DRT

- | | |
|--|---|
| 1 F150 Vision Mate Controller | 1 |
| 2 Setup Manual (this manual) | 1 |
| 3 Auto Menu Operation Manual | 1 |
| 4 Expert Menu Operation Manual | 1 |
| 5 CompoBus/D Connector (MSTB2.5/5-STF-5.08AU by Phoenix Contact) | 1 |

1-3 Product Availability

Some of the products listed may not be available in some countries. Please contact your nearest OMRON sales office by referring to the addresses provided at the back of this manual.

SECTION 2




Product Introduction

This section provides an overview of F150 application and describes the wiring, Cameras, optical lenses, lighting modes, and light guides used in the F150. It also describes how to mount the Vision Mate Controller to DIN Track or to a flat surface.

2-1	Overview of F150 Application	8
2-2	Component Names and Functions	9
2-3	Connections	12
2-4	Power Supply and Ground	13
2-4-1	Crimp Terminals and Cables	13
2-4-2	Protective Conductor (Earth) Wiring	13
2-4-3	Wiring the Power Supply	14
2-5	Cameras with Lights	15
2-6	CCTV Lens	17
2-6-1	Optical Chart	17
2-6-2	Lens	19
2-6-3	Extension Tubes	19
2-7	Lighting	20
2-7-1	Lighting Methods	20
2-8	Mounting the Controller	23
2-8-1	Mounting to DIN Track	23
2-8-2	Mounting on a Flat Surface	24

2-1 Overview of F150 Application


The following table shows the basic steps that must be performed to use the F150.

Step	Manual
<p>1: Unit Connections and Wiring</p>  <p>Programmable Controller</p> <p>Power Supply</p> <p>Video Monitor</p> <p>Console</p> <p>Synchronous sensor</p> <p>Camera with Light Source</p> <p>IBM PC/AT or compatible computer</p>	<p>Setup Manual</p>
<p>2: Setting Measurement Conditions</p>  <p>Video Monitor</p> <p>OK or NG</p> <p>OK NG or</p>	<p>Easy Operation: Auto Menu Operation Manual</p> <p>Advanced Operation: Expert Menu Operation Manual</p>
<p>3: Confirming Operation, Measuring Objects, and Outputting Results</p>  <p>IBM PC/AT or compatible computer</p> <p>Programmable Controller</p> <p>Video Monitor</p> <p>Synchronous sensor</p> <p>OK NG</p> <p>OK NG</p>	

2-2 Component Names and Functions

The following diagram shows the terminals, connectors, and indicators on the F150-C10E-2 and F150-C15E-2 Vision Mate Controller.


F150-C10E-2 F150-C15E-2



- | | |
|--|--|
| <p>① POWER Indicator
Lit while power is ON.</p> <p>② RUN Indicator
Lit in RUN mode.</p> <p>③ ERROR Indicator
Lit when an error occurs.</p> <p>④ RS-232C Connector
Connects the F150 to a computer, Programmable Controller, or other external device.</p> <p>⑤ Camera Connector
Connects to the Camera.</p> <p>⑥ Power Supply Terminals
Wired to the power supply.</p> | <p>⑦ Ground Terminal
Wired to the ground.</p> <p>⑧ Input Terminals
Wired to external devices, such as synchronous sensors or inputs from a Programmable Controller.</p> <p>⑨ Output Terminals
Wired to external devices, such as synchronous sensors or outputs to a Programmable Controller.</p> <p>⑩ Monitor Connector
Connects to the video monitor.</p> <p>⑪ Console Connector
Connects to the Console.</p> |
|--|--|

F150-C10E-2-DRT

The F150-C10E-2-DRT can operate as a CompoBus/D Slave.




-
- ① **POWER Indicator**
Lit while power is ON.
 - ② **RUN Indicator**
Lit in RUN mode.
 - ③ **ERROR Indicator**
Lit when an error occurs.
 - ④ **RS-232C Connector**
Connects the F150 to a computer, Programmable Controller, or other external device.
 - ⑤ **Camera Connector**
Connects to the Camera.
 - ⑥ **Power Supply Terminals**
Wired to the power supply.
 - ⑦ **Ground Terminal**
Wired to the ground.
 - ⑧ **Input Terminals**
Wired to external devices, such as synchronous sensors or inputs from a Programmable Controller.
 - ⑨ **Output Terminals**
Wired to external devices, such as synchronous sensors or outputs to a Programmable Controller.
 - ⑩ **Monitor Connector**
Connects to the video monitor.
 - ⑪ **Console Connector**
Connects to the Console.
 - ⑫ **MS (Module Status) Indicator**
Indicates the status of the F150 in CompoBus/D communications. Lit in green when the F150 is operating normally.
 - ⑬ **NS (Network Status) Indicator**
Indicates the status of the network in CompoBus/D communications. Lit in green when the network is operating normally.
 - ⑭ **DIP Switch**
Used to set the node address and baud rate.
 - ⑮ **CompoBus/D Connector**
Connects the communications cable of the CompoBus/D network.

2-3 Connections

Connect the basic components as shown in the following diagram. Details are provided later in this section.

Caution Turn OFF the power to the Controller before connecting or disconnecting cables. Connecting or disconnecting cables with power turned ON can damage peripheral devices.

Power Supply → p.14.
(OMRON's S82K-01524 and S82K-05024 recommended.)



Note 1. F150-SL Cameras are the same as F150-S1A Cameras except that they have a lens and a light attached.

2. If the field of vision is too small, use the F150-S1A Camera with a normal CCTV lens and light. → p. 17


2-4 Power Supply and Ground

Wire the power supply and the ground to the top terminal block, and tighten the screws to a torque of between 0.5 and 0.6 N·m. After wiring, confirm that wiring and screw tightening have been done properly.

Caution Cover the terminal blocks with the Terminal Block Protection Covers.

2-4-1 Crimp Terminals and Cables

The terminal block uses M3 terminal screws. Use appropriate crimp terminals for M3 screws, as shown below.




Applicable wire size: Insulated wire of 1.31 to 1.65 mm² (AWG16 to AWG15)

2-4-2 Protective Conductor (Earth) Wiring

Wire the ground as shown in the following diagram.

Caution Use an appropriate ground. An insufficient ground can affect F150 operation or result in damage to F150 components.

- To avoid damage to the equipment, do not share the protective conductor wiring with any other devices nor wire the protective conductor terminal to the girder. Be sure to wire the protective conductor of the equipment independently.
- Keep the ground line as short as possible.



2-4-3 Wiring the Power Supply


Caution Use a DC power supply with safe extra low-voltage circuits on the secondary side.

Use a power supply with the following specifications. We recommend using OMRON's S82K-01524 Power Supply.

Item	Specification
Output current	0.6 A min.
Power supply voltage	24 VDC $+10\%/-15\%$

Use a power supply that meets the following specifications when connecting an F150 and an F150-M05L LCD Monitor to a single power supply. We recommend using OMRON's S82K-05024 Power Supply.

Item	Specification
Output current	1.6 A min.
Power supply voltage	24 VDC $+10\%/-15\%$




- Note**
1. Wire the Power Supply Unit independently of other devices. In particular, keep the power supply wired separately from inductive loads.
 2. Keep the power supply cable as short as possible (less than 10 m).
 3. If UL recognition is required, use a UL class II power supply.

2-5 Cameras with Lights

The Cameras with Lights are special cameras with a lens and light attached. The light and lens are a single unit and are thus compact and easy to mount.

Cameras with F150-LT10A Light

The F150-SL20A and F150-SL50A are F150-S1A Cameras that are shipped with a lens and light attached.



Field of vision	Model
20 mm	F150-SL20A
50 mm	F150-SL50A

Camera Only

The same Camera is also available without a lens and light so that standard CCTV lenses and lights can be used. Use C-mount lenses.



Camera	Model
Camera	F150-S1A




Caution The F150-S1A Camera must be used with the F150. Using other Cameras can damage the F150 or the Camera.

Distance from Measurement Object

The Camera must be mounted at a distance from the measurement object where it can correctly view the object. The lens focus is fixed and the distance must be adjusted each time the lens or Camera is changed because the field of vision and focus vary from lens to lens.

The camera's set distance is an approximate value. The camera's mounting allows it to be adjusted slightly nearer to or farther from the object.

F150-SL20A/SL50A




Mounting the Camera


The specified camera distance is only an approximation. Mount the Camera so that it can be adjusted to either side of the specified distance from the measurement object.

Unit: mm

Camera with Light Source



Camera




If the object size and field of vision are incompatible, attach a standard CCTV lens and light to the Camera. → p. 17

2-6 CCTV Lens


When using a F150-S1A Camera (without a light), refer to the following graph to select the appropriate Lens and Extension Tube. The lens will differ depending on the size of the measurement object and the distance from the Camera.

2-6-1 Optical Chart

The values in the following chart are approximations, and the Camera must be adjusted after it is mounted.




The X axis of the graph shows field of vision L (mm), and the Y axis shows the camera distance A (mm). The curves on the graph indicate different lenses, and the "t" values indicates the lengths of the Extension Tubes.



2-6-2 Lens


Lens	Focal length	Brightness	Maximum outer diameter	Total length	Filter size
3Z4S-LE C418DX	4.8 mm	F1.8	40.5-mm dia.	35.5 mm	---
3Z4S-LE B618CX-2	6.5 mm	F1.8	48-mm dia.	42 mm	
3Z4S-LE C815B	8.5 mm	F1.5	42-mm dia.	40 mm	M40.5 × P0.5
3Z4S-LE B1214D-2	12.5 mm	F1.4	42-mm dia.	50 mm	
3Z4S-LE C1614A	16.0 mm	F1.4	30-mm dia.	33 mm	M27 × P0.5
3Z4S-LE B2514D	25.0 mm	F1.4	30-mm dia.	37.3 mm	
3Z4S-LE B5014A	50.0 mm	F1.4	48-mm dia.	48 mm	M46 × P0.75
3Z4S-LE B7514C	75.0 mm	F1.4	62-mm dia.	79 mm	M58 × P0.75




2-6-3 Extension Tubes

One or more Extension Tubes are inserted between the lens and the Camera to focus the Camera image. Use a combination of one or more of the six sizes of tube to achieve the required length.

- Note**
- Do not use the 0.5-mm and 1.0-mm Extension Tubes attached to each other. Since these Extension Tubes are placed over the threaded section of the Lens or other Extension Tube, the connection may loosen when more than one 0.5-mm or 1.0-mm Extension Tube are used together.
 - Reinforcement may be required for combinations of Extension Tubes exceeding 30 mm if the Camera is subject to vibration.



Model	Maximum outer diameter	Length
3Z4S-LE EX-C6	31 dia.	Set of 6 tubes 0.5 mm, 1 mm, 5 mm, 10 mm, 20 mm, and 40 mm



2-7 Lighting


A stable image must be obtained to ensure accurate inspection. Use appropriate lighting for the application and the measurement object if using the F150-S1A Camera.

2-7-1 Lighting Methods

Back Lighting

A stable, high-contrast image can be obtained using back lighting.


Applications: Inspection of exterior shape or positioning inspection



Reflected Lighting**Ring Lights**


Light is shone uniformly on the measurement object.

Applications: Surface inspections

**Oblique Lighting**

Detection can be made utilizing the difference in regular and diffuse reflected light.


Applications: Inspections for surface gloss



Coaxial Lighting

A stable image can be obtained with few shadows from uneven surfaces on the measurement object.

Applications: Surface inspections, positioning, and hole inspections of comparatively small objects




2-8 Mounting the Controller

The Vision Mate Controller can be mounted to DIN Track or a flat surface.

2-8-1 Mounting to DIN Track

The Vision Mate Controller can be easily mounted to or removed from 35-mm DIN Track.




The following DIN Tracks are available from OMRON.

Model	Length
PFP-100N	1 m
PFP-50N	50 cm
PFP-100N2	1 m


Mounting the Controller

Hook the Controller into the DIN Track as shown in the diagram and then press in at the bottom until the Controller locks into place.




Removing the Controller

Use a screwdriver to pull the hook down and then pull out the Controller from the bottom.



2-8-2 Mounting on a Flat Surface

Mount the Controller using the holes and dimensions shown in the following diagram.



Caution Do not use screw-locking materials that contain ingredients harmful to ABS or polycarbonate resins. The Controller will be damaged.

SECTION 3

Terminal Blocks

This section describes how to connect the terminal blocks.

3-1	Terminal Block Application	26
3-2	Crimp Terminals and Cables	26
3-3	Specifications	27
3-4	Terminals	28

3-1 Terminal Block Application

The following table shows the functions that can be performed by the F150-2 using the terminal blocks. Refer to the *Auto Menu* and *Expert Menu Operation Manuals* for communications settings and I/O formats.


3-2 Crimp Terminals and Cables

The terminal block uses M3 terminal screws. Use appropriate crimp terminals for M3 screws, as shown below. Tighten the screws to a torque of between 0.5 and 0.6 N·m.

Confirm that wiring and tightening have been done properly.

Use a cable length not exceeding 30 m.

 **Caution** Cover the terminal blocks with the Terminal Block Protection Covers.



Applicable wire size: Insulated wire of 1.31 to 1.65 mm² (AWG16 to AWG15)

3-3 Specifications

Caution Use a DC power supply with safe extra low-voltage circuits on the secondary side.

Input Specifications

Item	F150-C10E-2, F150-C10E-2-DRT (NPN model)	F150-C15E-2 (PNP model)
Input voltage	12 to 24 VDC $\pm 10\%$	
ON current	3 to 15 mA	
ON voltage	8.8 V max.	
OFF current	0.1 mA max.	
OFF voltage	4.5 V min.	
ON delay	RESET input: 10 ms max. Others: 0.5 ms max.	
OFF delay	RESET input: 15 ms max. Others: 0.7 ms max.	
Internal circuits		

Output Specifications


Item	F150-C10E-2, F150-C10E-2-DRT (NPN model)	F150-C15E-2 (PNP model)
Output voltage	12 to 24 VDC $\pm 10\%$	
Load current	45 mA max.	
ON residual voltage	2 V max.	
OFF leakage current	0.1 mA max.	
Internal circuits		

Note If UL recognition is required, use a UL class II power supply.


3-4 Terminals

The terminals on the terminal blocks are assigned as shown in the following diagrams and tables.

F150-C10E-2 F150-C15E-2




Top Terminals



Name/Application		Name/Application	
RUN		ERR	Error output
BUSY		GATE	
OR		NC	Not connected
COM OUT (*1)	For RUN, ERR, BUSY, GATE, and OR	RESET	Resets F150-2
DSA	Command inputs	STEP	
DI 0		DI 1	Command inputs
DI 2		DI 3	
DI 4		DI 5	
DI 6		DI 7	
COM IN		---	

Bottom Terminals




Name/Application		Name/Application	
DO 1	Measurement results output	DO 0	Measurement results output
DO 3		DO 2	
DO 5		DO 4	
DO 7		DO 6	
NC	Not connected	COM OUT (*2)	For DO 0 to DO 7
DO 9	Measurement results output	DO 8	Measurement results output
DO 11		DO 10	
DO 13		DO 12	
DO 15		DO 14	
---		COM OUT (*3)	For DO 8 to DO 15

Caution Do not input the RESET input immediately after turning ON the power. When using RESET input to synchronize execution timing, wait at least 1 s after turning ON the F150-2 power supply before turning ON the RESET terminal.

Caution Do not reverse the connections of the signal terminals and COM terminals.

F150-C10E-2-DRT



Name/Application		Name/Application	
RUN		ERR	Error output
BUSY		GATE	
OR		NC	Not connected
COM OUT		RESET	Resets F150-2
NC	Not connected	STEP	
NC		NC	Not connected
NC		NC	
NC		NC	
NC		NC	
COM IN		---	

Caution Do not input the RESET input immediately after turning ON the power. When using RESET input to synchronize execution timing, wait at least 1 s after turning ON the F150-2 power supply before turning ON the RESET terminal.

Caution Do not reverse the connections of the signal terminals and COM terminals.

SECTION 4

RS-232C Connection

This section describes how to connect the RS-232C port.


4-1	RS-232C Port Application	32
4-2	Connector	32
4-3	Wiring	33
4-4	Connection	34

4-1 RS-232C Port Application

The following table shows the functions that can be performed by the F150 via the RS-232C port. Refer to the *Auto Menu* and *Expert Menu Operation Manuals* for communications settings, I/O formats, and operating procedures.

4-2 Connector

Use an appropriate 9-pin D-SUB female connector. The pin numbers and names are shown below.



Pin	Signal	Name
1	FG (GND)	Frame ground
2	SD (TXD)	Send Data
3	RD (RXD)	Receive Data
4	RS (RTS)	Request to Send
5	CS (CTS)	Clear to Send
6	NC	Not connected
7	NC	Not connected
8	NC	Not connected
9	SG (GND)	Signal ground


The following plug and hood are recommended and are available from OMRON.

Model	Model No.
Plug	XM2A-0901
Hood	XM2S-0911


4-3 Wiring

Use only shielded RS-232C cable.

Standard Connections



Connections for RS/CS Control




Note Pin numbers on the external device will depend on the device being connected. Refer to the manual for the device being connected.

4-4 Connection

Align the connector with the socket and press the connector straight into place. Tighten the two screws on the edges of the connector.

Caution Always turn OFF the power supply before connecting or disconnecting cables. Peripheral devices can be damaged if connected or disconnected with the power supply turned ON.



Note Always tighten the connector screws.

SECTION 5

CompoBus/D Connections

This section describes how to connect the F150-C10E-2-DRT Vision Sensor as a CompoBus/D Slave and provides information such as connector pin allocations, node number settings, and baud rate settings.

Refer to the *CompoBus/D (DeviceNet) Operation Manual (W267-E1-4)* for details on CompoBus/D communications specifications.

Refer to the *Auto Menu Operation Manual* or *Expert Menu Operation Manual* for details on setting the Vision Sensor's communications specifications and changing the I/O format.


5-1	Overview	36
5-2	Communications Specifications	40
5-3	DIP Switch Settings	41
5-4	Connector Pin Allocation	43
5-5	LED Indicators	44
5-6	Multi-vendor Applications	44

5-1 Overview

CompoBus/D is a multi-bit, multi-vendor network that conforms to DeviceNet open field network specifications. The F150-C10E-2-DRT Vision Sensor operates as a CompoBus/D Slave and data is automatically transferred between the Slave and Master by remote I/O communications.


The number of I/O bytes handled by the Vision Sensor depends upon the communications specifications settings, so be sure to set the Vision Sensor's communications specifications before registering the Master's scan list.

Refer to the *Auto Menu Operation Manual* or *Expert Menu Operation Manual* for details on setting the Vision Sensor's communications specifications and changing the I/O format.




Output Area

Write commands are directed to the F150 in this area. The number of bytes in the area depends upon the input mode (basic or expand) that is selected.




Only a few words are occupied. Commands such as the measurement and scene change commands can be used.
(Only basic mode can be used with the Auto Menu.)



A variety of commands other than the measurement command can be used, such as parameter setting and reading commands. Various F150's functions can be used.

Input Area

The measurement results (execution results) from the F150 are output to this area.



These outputs can be enabled or disabled. When the “expand command response output” is disabled, the data output will be shifted up to word +3.


5-2 Communications Specifications

Item		Specification
Communications protocol		DeviceNet
Supported connections (see note 1) (communications)		Master-Slave: Remote I/O communications and explicit message/communications
Connection formats (see note 2)		Multi-drop and T-branch connections can be combined (for trunk or drop lines)
Baud rate		125K bps, 250K bps, or 500K bps (Set on the DIP switch.)
Communications media		Special 5-conductor cable (2 signal lines, 2 power lines, 1 shield)
Communications distances	500K bps	Network length: 100 m max. (see note 3) Drop line length: 6 m max. Total drop line length: 39 m max.
	250K bps	Network length: 250 m max. (see note 3) Drop line length: 6 m max. Total drop line length: 78 m max.
	125K bps	Network length: 500 m max. (see note 3) Drop line length: 6 m max. Total drop line length: 156 m max.
Communications power supply		11 to 25 VDC
Node number		0 to 63 (Set on the DIP switch.)
Words used in Master (see note 4)	Output area	1 word (2 bytes) or 5 words (10 bytes) (Set to 1 word when shipped.)
	Input area	3 words (6 bytes), 8 words (16 bytes), 27 words (54 bytes), or 32 words (64 bytes) (Set to 3 words when shipped.)
Error control checks		CRC error check

- Note**
1. Only remote I/O communications are supported in the Vision Sensor's Auto Menu and Expert Menu. Explicit message communications are not supported.
 2. A terminator must be connected at each end of the trunk line.
 3. These values are valid when thick cable is used for the trunk line. The maximum network length is 100 m max. when thin cable is used.
 4. Set the number of words in the Menu. Reset the entire network after changing these settings.

5-3 DIP Switch Settings

The node address and baud rate are set on the DIP switch. Be sure to turn OFF the power supply (including the communications power supply) before changing DIP switch settings.




Note Set the same baud rate on all nodes (Master and Slaves) in the network. If the F150 is not set to the correct baud rate, it will be unable to participate in the network and communications errors may occur in communications between nodes with correct node address settings.

Node Address Setting (0 to 63)

Set the node address in binary with pins 1 through 6. These pins have values of 1, 2, 4, 8, 16, and 32 (left to right). The node address is set to 0 when the Sensor is shipped.


The following diagram shows the node address set to 10. The pins with values 2 and 8 are turned ON.



Baud Rate Setting (125K bps, 250K bps, or 500K bps)

Pins 7 and 8 set the baud rate as shown in the following diagrams.

- 125K bps (factory setting)






- 250K bps



- 500K bps



5-4 Connector Pin Allocation



Name	Function	Color
V-	Power supply line (-)	Black
CAN L	Communications data (Low)	Blue
Shield	Shield	---
CAN H	Communications data (High)	White
V+	Power supply line (+)	Red

Refer to the *CompoBus/D (DeviceNet) Operation Manual* for details on assembling a communications cable.

- Note**
1. Turn OFF the power supply before connecting or disconnecting the cable. Peripheral devices may be damaged if the cable is connected or disconnected with the power ON.
 2. Securely tighten the connector screws.

5-5 LED Indicators

The status of CompoBus/D communications is indicated by the MS and NS indicators.

MS (Module Status) Indicator

The MS indicator shows the status of node (F150) itself. The indicator will be lit green when the F150 is operating normally.

NS (Network Status) Indicator

The NS indicator shows the status of network. The indicator will be lit green when the network is operating normally.

Note The MS and NS indicators are lit in green or red. The status of these indicators (lit, flashing, or not lit) can be used to determine what error has occurred.

→ p. 54

5-6 Multi-vendor Applications

Use the Vision Sensor's specifications as well as the Device Protocol and Object Mounting information shown in the following tables when the F150-C10E-2-DRT is connected to another company's Master.

Device Protocol

General data	Compatible DeviceNet Specifications	Volume I - Release 2.0 Volume II - Release 2.0
	Vendor name	OMRON Corporation, vendor ID = 47
	Device type	Generic, protocol number = 0
	Product code	203
Physical conformance data	Network current consumption	55 mA max.
	Connector type	Open plug
	Physical insulation	Yes
	Supported indicators	Module, Network
	MAC ID setting	DIP switch
	Default MAC ID	0
	Baud rate setting	DIP switch
	Supported baud rates	125K bps, 250K bps, and 500K bps
Communications data	Predefined Master/Slave connection set	Group 2 only server
	Dynamic connection support (UCMM)	No
	Explicit message fragmentation support	Yes

Object Mounting

Identity Object (0x01)

Object class	Attribute	Not supported
	Service	Not supported

Item		ID content	Get (read)	Set (write)	Value
Object instance	Attribute	1 Vendor	Yes	No	47
		2 Product type	Yes	No	0
		3 Product code	Yes	No	203
		4 Revision	Yes	No	2.1
		5 Status (bits supported)	Yes	No	Bit 0 and bit 10
		6 Serial number	Yes	No	Unique for each Unit
		7 Product name	Yes	No	F150-C10E-2
		8 State	No	No	---

Item		DeviceNet service	Parameter option
Object instance	Service	05 Reset	No
		0E Get_Attribute_Single	No

Message Router Object (0x02)

Object class	Attribute	Not supported
	Service	Not supported
Object instance	Attribute	Not supported
	Service	Not supported
Vendor specification addition		No

DeviceNet Object (0x03)

Item		ID content	Get (read)	Set (write)	Value
Object instance	Attribute	1 Revision	Yes	No	02 (hexadecimal)

Item		DeviceNet service	Parameter option
Object class	Service	0E Get_Attribute_Single	No

Item		ID content	Get (read)	Set (write)	Value
Object instance	Attribute	1 MAC ID	Yes	No	---
		2 Baud rate	Yes	No	---
		3 BOI	Yes	No	00 (hexadecimal)
		4 Bus Off counter	Yes	No	---
		5 Allocation information	Yes	No	---
		6 MAC ID switch changed	No	No	---
		7 Baud rate switch changed	No	No	---
		8 MAC ID switch value	No	No	---
		9 Baud rate switch value	No	No	---

Item		DeviceNet service	Parameter option
Object instance	Service	0E Get_Attribute_Single	No
		4B Allocate_Master/Slave_Connection_Set	No
		4C Release_Master/Slave_Connection_Set	No

Assembly Object (0x04)

Object class	Attribute	Not supported
	Service	Not supported

Item	Section	Information	Max. number of instances
Object instance 1	Instance type	Static I/O	1

Item		Content	Get (read)	Set (write)	Value
Object instance 1	Attribute	1 Number of Members in List	No	No	---
		2 Members List	No	No	---
		3 Data	Yes	Yes	---

Item		DeviceNet service	Parameter option
Object instance 1	Service	0E Get_Attribute_Single	No
		10 Set_Attribute_Single	No

Connection Object (0x05)

Object class	Attribute	Not supported
	Service	Not supported
	Max. number of active connections	1

Item	Section	Information	Max. number of instances
Object instance 1	Instance type	Explicit Message	1
	Production trigger	Cyclic	---
	Transport type	Server	---
	Transport class	3	---

Item		ID content	Get (read)	Set (write)	Value
Object instance 1	Attribute	1 State	Yes	No	---
		2 Instance type	Yes	No	00 (hexadecimal)
		3 Transport class trigger	Yes	No	83 (hexadecimal)
		4 Produced connection ID	Yes	No	---
		5 Consumed connection ID	Yes	No	---
		6 Initial comm. characteristics	Yes	No	21 (hexadecimal)
		7 Produced connection size	Yes	No	FE00 (hexadecimal)
		8 Consumed connection size	Yes	No	FE00 (hexadecimal)
		9 Expected packet rate	Yes	Yes	---
		12 Watchdog time-out action	Yes	Yes	One of 01, 03
		13 Produced connection path length	Yes	---	0000
		14 Produced connection path	Yes	No	---
		15 Consumed connection path length	Yes	No	0000
		16 Consumed connection path	Yes	No	---
17 Production inhibit time	Yes	No	---		

Item		DeviceNet service	Parameter option
Object instance 1	Service	05 Reset	No
		0E Get_Attribute_Single	No
		10 Set_Attribute_Single	No

Item	Section	Information	Max. number of instances
Object instance 2	Instance type	Polled I/O	1
	Production trigger	Cyclic	---
	Transport type	Server	---
	Transport class	2	---

Item		ID content	Get (read)	Set (write)	Value
Object instance 2	Attribute	1 State	Yes	No	---
		2 Instance type	Yes	No	01 (hexadecimal)
		3 Transport class trigger	Yes	No	82 (hexadecimal)
		4 Produced connection ID	Yes	No	---
		5 Consumed connection ID	Yes	No	---
		6 Initial comm. characteristics	Yes	No	01 (hexadecimal)
		7 Produced connection size	Yes	No	See note 1.
		8 Consumed connection size	Yes	No	See note 2.
		9 Expected packet rate	Yes	Yes	---
		12 Watchdog time-out action	Yes	No	00
		13 Produced connection path length	Yes	No	0000 (No inputs) 0600 (With inputs)
		14 Produced connection path	Yes	No	No data (no inputs) 20_04_24_01_ 30_03 (with inputs)
		15 Consumed connection path length	Yes	No	0000 (no outputs) 0600 (with outputs)
		16 Consumed connection path	Yes	No	No data (no outputs) 20_04_24_01_ 30_03 (with outputs)
17 Production inhibit time	Yes	No	00		

- Note**
1. Indicates the number of input bytes used by the Slave. The leftmost and rightmost bytes are reversed. (For example, the produced connection size = 4000 when 64 bytes are used.)
 2. Indicates the number of output bytes used by the Slave. The leftmost and rightmost bytes are reversed. (For example, the consumed connection size = 4000 when 64 bytes are used.)

Item		DeviceNet service	Parameter option
Object instance 2	Service	05 Reset	No
		0E Get_Attribute_Single	No
		10 Set_Attribute_Single	No

Item	Section	Information	Max. number of instances
Object instance 3	Instance type	Bit strobed I/O	1
	Production trigger	Cyclic	---
	Transport type	Server	---
	Transport class	2	---

Item		ID content	Get (read)	Set (write)	Value
Object instance 3	Attribute	1 State	Yes	No	---
		2 Instance type	Yes	No	01 (hexadecimal)
		3 Transport class trigger	Yes	No	82 (hexadecimal)
		4 Produced connection ID	Yes	No	---
		5 Consumed connection ID	Yes	No	---
		6 Initial comm. characteristics	Yes	No	02 (hexadecimal)
		7 Produced connection size	Yes	No	See note.
		8 Consumed connection size	Yes	No	0800 (hexadecimal)
		9 Expected packet rate	Yes	Yes	---
		12 Watchdog time-out action	Yes	No	00
		13 Produced connection path length	Yes	No	0600
		14 Produced connection path	Yes	No	20_04_24_01_30_03
		15 Consumed connection path length	Yes	No	0000
		16 Consumed connection path	Yes	No	No data
17 Production inhibit time	Yes	No	00		

Note Indicates the number of input bytes used by the Slave. The left-most and rightmost bytes are reversed. (For example, the produced connection size = 0800 when 8 bytes are used.)
 With the bit-strobed interface, the maximum produced connection size is 8 bytes. A produced connection size of 8 bytes (0800) will be used if a higher value has been set for the number of input bytes with the user MPU; the set value will be used if it is 8 bytes or less.

Item		DeviceNet service	Parameter option
Object instance 3	Service	05 Reset	No
		0E Get_Attribute_Single	No
		10 Set_Attribute_Single	No

SECTION 6

Troubleshooting

This section lists the errors that may occur, along with their probable causes and remedies.

6-1	Connection Errors	52
6-2	Errors during Menu Operation	52
6-3	Terminal Block Errors	52
6-4	RS-232C Communications Errors	53
6-5	LED Indicators	54

6-1 Connection Errors

Problem	Probable cause
The POWER indicator is not lit.	The Power Supply is not connected properly.
	The supply voltage is not 24 VDC $+10\%$ / -15% .
The Video Monitor is blank.	The power to the Video Monitor is not ON.
	The Monitor Cable is not connected properly.
	The Video Monitor is malfunctioning.
	When using an LCD Monitor, the power supply capacity is insufficient.
Cannot make key inputs from the Console.	The Console Cable is not correctly connected.
Camera images do not appear on the screen (for Cameras with Light Source).	The Camera Cable is not correctly connected.
	The lighting cable is not properly connected to the Camera.
Camera images do not appear on the screen (when a normal CCTV lens and lighting is used).	The lens cap has not been removed.
	The Camera Cable is not properly connected.
	The lens diaphragm is opened or closed too far.
	The shutter speed is not suitable.
	The lighting method is not suitable.
The indicators do not turn ON (for Cameras with Light Source).	The lighting cable is not correctly connected to the Camera.
	There is no power supply to the F150.
The Video Monitor image is not clear.	There is electrical noise entering from the power supply or cables.
	The Monitor Cable is not correctly connected.

6-2 Errors during Menu Operation

Problem	Probable cause
The measurement results are not displayed on the Video Monitor.	The F150 is not in Monitor or Run mode.

6-3 Terminal Block Errors

Problem	Probable cause
Trigger signals (input signals) are not received.	The cables are not correctly wired.
	The signal line is disconnected.
	The F150 is not in Monitor or Run mode.
Signals cannot be output externally.	The trigger signal has not been input.
	The cables are not correctly wired.
	The signal line is disconnected.
	The F150 is not in Run mode.

6-4 RS-232C Communications Errors

Problem	Probable cause
No communications are possible.	The cables are not correctly wired.
	The communications specifications do not match those of the external device.
	The communications mode was not selected under System/Communications settings . Select Normal , Host link , or Menu operations under RS-232C/Operating mode .
The Unit operates well initially, but after a while there is no response from the F150.	The reception buffer on the external device (e.g., computer) is full. Check that settings allow the data to be properly received.
Cannot perform menu operations via RS-232C.	The communications mode was not selected as System/Communications settings/Menu operations .

6-5 LED Indicators

Indicator Status		Condition	Remarks	
MS	NS			
Lit green	Lit green	Remote I/O communications in progress.	Communications are operating normally.	
	OFF	Node number duplication check in progress.	Check for the following problems and restart the F150. <ul style="list-style-type: none"> • Are the baud rate settings the same on the Master and F150? • Are the cable lengths (trunk and branch lines) within specifications? 	
	Flashing green	Waiting for connection to be established by Master.	<ul style="list-style-type: none"> • Are any cables loose or broken? • Is there a terminator on each end of the trunk line? • Is there excessive noise in the network? 	
	Lit red	Lit red	Node number duplication	Change the node number settings to eliminate the duplication and then restart the entire CompoBus/D network.
			Bus off occurred. (Communications stopped due to excessive data errors.)	Check for the following problems and restart the F150. <ul style="list-style-type: none"> • Are the baud rate settings the same on the Master and F150? • Are the cable lengths (trunk and branch lines) within specifications?
Flashing red	Flashing red	Communications timeout occurred.	<ul style="list-style-type: none"> • Are any cables loose or broken? • Is there a terminator on each end of the trunk line? • Is there excessive noise in the network? 	
Lit red	OFF	Watchdog timer error occurred in the F150.	The F150 is faulty. Replace the F150.	
Flashing red	OFF	Incorrect setting on the DIP switch or elsewhere.	Check the switch settings and restart the F150.	

SECTION 7

Maintenance

This section provides information on maintenance and inspection.

7-1	Maintenance Parts and Replacement	56
7-2	Regular Inspections	57


7-1 Maintenance Parts and Replacement

Maintenance parts of the F150 are shown in the following table.

Part	Model No.
20-mm Lens (20 mm × 20 mm)	F150-LE20
50-mm Lens (50 mm × 50 mm)	F150-LE50
Light	F150-LT10

- Note**
1. The Light will gradually lose illumination if used for long periods (approx. 20% loss after 1,500 hours of use). Replace the Light after approx. 1,500 hours of use.
 2. Replace the Light if it is partially damaged or not fully functioning.

Replacing the Lens or Light



- 1 Disconnect the light cable from the light connector on the back of the Camera.
- 2 Remove the light cable from the slot in the camera base.
- 3 Remove the two M3 × 6 screws securing the Light.
- 4 Remove the Light from the Camera.
- 5 Remove the Lens from the camera mount.

Note Follow these steps in the reverse order to mount the Lens and Light.



Caution Do not disassemble the Lens. Disassembly can damage the Lens.

7-2 Regular Inspections

To maintain the F150 in the best condition, perform the following regularly.

- Lightly wipe off dirt with a soft cloth.
- Clean the Lens and indicators with a special lens cloth or air-brush.

Inspection point	Details	Tools required
Power supply	The voltage measured at the power supply terminals on the terminal block must be 24 VDC $+10\%$ / -15% .	Circuit tester
Ambient temperature	The operating ambient temperature inside the cabinet must be between 0 and 50°C.	Thermometer
Ambient humidity	The operating ambient humidity inside the cabinet must be between 35% and 85%.	Hygrometer
Installation	Each component must be firmly secured. Each cable connector must be correctly inserted and locked. The Cameras must be firmly secured. The camera lens mounts must be firmly secured.	Phillips screwdriver
Indicators	All indicators must light when the power is turned ON.	---



Caution Turn OFF the power and take safety precautions before conducting inspections. Electrical shock can result from attempting safety inspections with the power turned ON.



Caution Do not use thinners or benzene. They will damage F150 components.

SECTION 8


Specifications

This section provides the specifications of the F150 components.

8-1	F150 Vision Mate Controller	60
8-2	K150-KP Console	62
8-3	Cameras	63
8-4	F150-LE20/50 Lens	65
8-5	F150-LT10A Light	65
8-6	Cables	66
8-7	F300-M09 Video Monitor	67
8-8	LCD Monitor	68

8-1 F150 Vision Mate Controller


F150-C10E-2, F150-C15E-2



Item	Specification	
Model	F150-C10E-2	F150-C15E-2
Input/Output type	NPN	PNP
Supply voltage	24 VDC (+10%, -15%)	
Current consumption	Approx. 0.5 A	
Insulation resistance	20 M Ω min. between all DC external terminals and GR terminal (at 100 VDC, with internal surge absorber removed)	
Dielectric strength	1,000 VAC, 50/60 Hz between all DC external terminals and GR terminal (with internal surge absorber removed)	
Leakage current	10 mA max.	
Noise resistance	1500 Vp-p; pulse width: 0.1 μ s/ 1 μ s; rising time: 1 ns (pulse)	
Vibration resistance	10 to 150 Hz; half-amplitude: 0.5 mm; maximum acceleration: 70 m/s ² , 4 times for 8 minutes each in 3 directions	
Shock resistance	200 m/s ² , 3 times each in 6 directions	
Ambient temperature	0 to 50 °C	
Ambient humidity	35% to 85% (with no condensation)	
Ambient environment	No corrosive gases	
Storage temperature	-25 to 65 °C	
Protection class	Class I (with protective conductor terminal)	
Degree of protection	IEC60529 IP20 (in-panel)	
Weight	Approx. 390 g (without cable)	


F150-C10E-2-DRT

The F150-C10E-2-DRT can operate as a CompoBus/D Slave.



Item	Specification
Supply voltage	24 VDC (+10%, -15%)
Current consumption	Approx. 0.5 A
Insulation resistance	20 MΩ min. between all DC external terminals and GR terminal (at 100 VDC, with internal surge absorber removed)
Dielectric strength	1,000 VAC, 50/60 Hz between all DC external terminals and GR terminal (with internal surge absorber removed)
Leakage current	10 mA max.
Noise resistance	1500 Vp-p; pulse width: 0.1μs/ 1μs; rising time: 1 ns (pulse)
Vibration resistance	10 to 150 Hz; half-amplitude: 0.5 mm; maximum acceleration: 70 m/s ² , 4 times for 8 minutes each in 3 directions
Shock resistance	200 m/s ² , 3 times each in 6 directions
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
Protection class	Class I (with protective conductor terminal)
Degree of protection	IEC60529 IP20 (in-panel)
Weight	Approx. 390 g (without cable)


8-2 K150-KP Console




Item	Specification
Vibration resistance	10 to 150 Hz; half-amplitude: 0.15 mm
Shock resistance	196 m/s ²
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
Degree of protection	IEC60529 IP20 (in-panel)
Length	2 m
Minimum bending radius	75 mm
Weight	Approx. 135 g

8-3 Cameras


F150-SL20A/SL50A (Camera with an F150-LT10A Light)



Mounting dimensions



F150-S1A Camera



Item		Specification
Supply voltage		12 VDC
Current consumption		Approx. 160 mA
Vibration resistance		10 to 150 Hz; half-amplitude: 0.5 mm; maximum acceleration: 70 m/s ² , 4 times for 8 minutes each in 3 directions
Shock resistance		200 m/s ² , 3 times each in 6 directions
Ambient temperature		0 to 50 °C
Ambient humidity		35% to 85% (with no condensation)
Ambient environment		No corrosive gases
Storage temperature		-25 to 60 °C
Picture element		1/3" Interline CCD (reading all pixels)
Effective pixels		659 × 494 (H × V)
Synchronization		External sync. via horizontal sync signal
Shutter speed		Electronic shutter: 1/100 s, 1/500 s, 1/2000 s, 1/10000 s
Lens mounting		C mount
Weight	Camera with Light Source	F150-SL20A/SL50A: Approx. 135 g
	Camera only	Approx. 70 g

8-4 F150-LE20/50 Lens

Item	Specification
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
System	Fixed focus, fixed diaphragm
Brightness	LE20/50: F2.8
Field of vision	LE20: 20 mm × 20 mm LE50: 50 mm × 50 mm
Focal distance	LE20: 13 mm LE50: 6.1 mm
Camera distance	LE20: 61 to 71 mm LE50: 66 to 76 mm

8-5 F150-LT10A Light

Item	Specification
Supply voltage	12 VDC
Current consumption	Approx. 10 mA
Insulation resistance	20 M Ω min. between all DC external terminals and case (at 100 VDC)
Dielectric strength	1,000 VAC, 50/60 Hz between all DC external terminals and case
Leakage current	10 mA max.
Vibration resistance	10 to 150 Hz; half-amplitude: 0.5 mm; maximum acceleration: 70 m/s ² , 4 times for 8 minutes each in 3 directions
Shock resistance	200 m/s ² , 3 times each in 6 directions
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
Light elements	LEDs
Lighting system	Pulse

8-6 Cables

F150-VS Camera Cable


Item	Specification
Vibration resistance	10 to 150 Hz; half-amplitude: 0.15 mm, 4 times for 8 minutes each in 3 directions
Shock resistance	196 m/s ² , 3 times each in 6 directions
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
Length	3 m
Minimum bending radius	75 mm

F150-VM Monitor Cable

Item	Specification
Vibration resistance	10 to 150 Hz; half-amplitude: 0.15 mm, 4 times for 8 minutes each in 3 directions
Shock resistance	196 m/s ² , 3 times each in 6 directions
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
Length	2 m
Minimum bending radius	50 mm

8-7 F300-M09 Video Monitor

This is the recommended monitor and is available from OMRON.






Item	Specification
Supply voltage	100 VAC
Current consumption	Approx. 300 mA
Vibration resistance	10 to 150 Hz; half-amplitude: 0.15 mm, 4 times for 8 minutes each in 3 directions
Shock resistance	196 m/s ² , 3 times each in 6 directions
Ambient temperature	0 to 40 °C
Ambient humidity	10% to 90% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	-25 to 65 °C
System	Number of scanning lines: 525 Horizontal frequency: 15.75 kHz Field frequency: 60 Hz
I/O impedance	75 Ω, high impedance (selectable)
I/O level and polarity	Image: 0.7 V (peak to peak), positive Synchronization: 0.3 V (peak to peak), negative
Screen size	123 × 164 (H × W), monochrome (light-holding)
Resolution	700 TV lines min. (at center)
Weight	Approx. 5.8 kg

8-8 LCD Monitor

F150-M05L

Unit: mm


Mounting plate thickness: 1.6 to 4.8



Tolerance: ± 1 mm

The dimensions in parentheses are provided for reference.

Panel opening dimensions




Item	Specification
Supply voltage	24 VDC (+10%/−15%)
Power consumption	15 W max.
Current consumption	700 mA max.
Vibration resistance	10 to 150 Hz; half-amplitude: 0.1 mm, 10 times for 8 minutes each in 3 directions
Shock resistance	150 m/s ² , 3 times each in 6 directions
Ambient temperature	0 to 50 °C
Ambient humidity	35% to 85% (with no condensation)
Ambient environment	No corrosive gases
Storage temperature	−25 to 65 °C
Panel size	5.5 inches
Panel type	TFT
Resolution	320 × 240 dots
Image pitch	0.348 × 0.348 mm (H × V)
Image size	111.36 × 83.52 mm (H × V)
Contrast	83:1 (typical)
Viewable angle	25° up/down and 50° left/right (with a contrast ratio > 10)
Luminance	250 cd/m ² (typical)
Backlight	Cold cathode fluorescent light
Response speed	60 ms max.
Input signal	NTSC composite video (1.0 V/75 Ω termination)
Weight	Approx. 1 kg

Revision History

A manual revision code appears as a suffix to the catalog number on the front cover of the manual.

Cat. No. Z132-E1-02



The following table outlines the changes made to the manual during each revision. Page numbers refer to the previous version.

Revision code	Date	Revised content
1	May 1999	Original production
1A	February 2000	<p>Changes were made on the following pages:</p> <p>Thought the manual: "F150-2" changed to "F150" and "Warnings" changed to "Cautions."</p> <p>Page v: "Electric Shock" information removed.</p> <p>Page ix: Manual numbers changed.</p> <p>Pages 9, 11 : "PLC" changed to "Programmable Controller."</p> <p>Page 12: Graphics added and changes made to model numbers.</p> <p>Page 13: Change to description of ground resistance.</p> <p>Pages 13, 26: Change to wire size information.</p> <p>Page 14: Information on power supplies added.</p> <p>Page 14-16: Major changes to 2-5.</p> <p>Page 16, 19: Changes to model numbers.</p> <p>Page 18: Extension tube graphic changed.</p> <p>Page 27: Minor changes to graphics.</p> <p>Pages 29, 30: Changes to cautionary information.</p> <p>Page 52: Information added to first table. Information on Camera, lighting, and monitor errors added.</p> <p>Page 57: "RH" deleted from table.</p> <p>Page 60: "Input" added to table.</p> <p>Pages 60, 61, 62, 64, 65, 66, 67: "Single amplitude" changed to "half-amplitude."</p> <p>Page 62: Minor change to graphic. Weight information changed.</p> <p>Page 63: Major changes to 8-3.</p> <p>Page 64: Weight information removed.</p> <p>Page 67: Dimension added to graphic.</p> <p>Page 68: Information on Monitor added.</p>
02	May 2004	<p>Page ix: Suffixes removed from catalog numbers.</p> <p>Page 14: Information added to note 2.</p> <p>Page 17: Figure changed.</p> <p>Page 26: Information added before caution.</p>



OMRON ELECTRONICS LLC

1 Commerce Drive
Schaumburg, IL 60173
847.843.7900

For US technical support or
other inquiries: 800.556.6766

OMRON CANADA, INC.

885 Milner Avenue
Toronto, Ontario M1B 5V8
416.286.6465

OMRON ON-LINE

Global - <http://www.omron.com>
USA - <http://www.omron.com/oei>
Canada - <http://www.omron.ca>

UNITED STATES

To locate a Regional Sales Office, local Distributor or
to obtain product information, call: 847.843.7900

CANADA REGIONAL SALES OFFICES

Ontario	Toronto	416.286.6465
	Kitchener	519.896.1144
	Kingston	613.376.3968
Quebec	Montreal	514.636.6676
British Columbia	Vancouver	604.522.8855
Alberta	Edmonton	403.440.0818
	Calgary	403.257.3095

BRAZIL SALES OFFICE

Sao Paulo 55.11.5564.6488

ARGENTINA SALES OFFICE

Cono Sur 54.114.787.1129

MEXICO SALES OFFICES

Florida 954.227.2121 Ciudad Juarez 656.623.7083
Mexico, D.F. 555.534.1195 Monterrey, N.L. 818.377.4281