

POWER-ON COUNTER POWER-ON HOUR METER

KC2S Eco-COUNT METER **KE2S Eco-HOUR METER**

Eco-COUNT METER and Eco-HOUR METER are ideal for maintenance of your facilities and machinery.



Eco-COUNT METER





FEATURES

1. Easy to install on existing machinery Just attach the dedicated CT to your existing cables. There is no need to install any additional cabling. 2. Built-in battery The built-in battery allows the units to be

installed anywhere. 3. Economically priced

4. Compact size doesn't take up space (DIN 24 x 48)

Easy to install even in cramped spaces.

5. Two installation methods available (Separate models)

Two installation methods are available: The extremely easy-to-use one-touch installation, and the installation frame installation, used for timers/counters (protective construction IP66). Select the installation type that suits the location.

6. Letter's height is 8.7 mm

A large LCD panel is used, with a highly legible 8.7 mm letter's height. 7. Conform to CE marking (EMC directive)

PRODUCT TYPES

1. KC2S Eco-COUNT METER

| Product Name | Installation type | Front reset | Measurement count range | Part No. |
|-----------------------------|-----------------------------|-------------|-------------------------|----------|
| Eco-COUNT METER main unit*1 | Installation frame type*2 | Available | 0 to 99999999 | AKC2421 |
| | One-touch installation type | Available | 0 10 99999999 | AKC2621 |
| Intermediate power cable*3 | — | | AKE2811 | |

Notes: 1. Eco-COUNT METER (AKC2421/AKC2621) is a product package consisting of the main unit, a dedicated current transformer (CT), and trunk cable.

2. Only the installation frame installation type includes rubber gasket and installation frame. 3. The maximum allowable current of the intermediate power cable is 15 A.

2. KE2S Eco-HOUR METER

| Product Name | Installation type | Front reset | Measurement time range | Part No. |
|----------------------------|-----------------------------|-------------|------------------------|----------|
| Eco-HOUR METER main unit*1 | Installation frame type*2 | Available | 0 to 99999.9h | AKE2421 |
| | One-touch installation type | | | AKE2621 |
| Intermediate power cable*3 | _ | | AKE2811 | |

Notes: 1. Eco-HOUR METER (AKE2421/AKE2621) is a product package consisting of the main unit, an exclusive use current transformer (CT), and trunk cable. 2. Only the installation frame type includes rubber gasket and installation frame.

3. The maximum allowable current of the intermediate power cable is 15 A.

SPECIFICATIONS

| | Item | Specifications | | | |
|---|-----------------------------|--|--|--|--|
| Product name | | Eco-COUNT METER (Power-on Counter) | Eco-HOUR METER (Power-on Hour Meter) | | |
| Part No. | | AKC2421/AKC2621 | AKE2421/AKE2621 | | |
| No. of digits | | 8 digits | 6 digits | | |
| External pow | er supply | Not required (built-in battery) | | | |
| Counting max | k. speed | 2Hz (CT through current minimum power-up time: 250ms, ON:OFF =1:1) | | | |
| Time accurac | х у | _ | ±100ppm (25°C) | | |
| Measuremen | t range | 0 to 99999999 counts | 0 to 99999.9h | | |
| Detection sensitivity (through current) | | Counting start: 0.5A to 80A (50/60Hz)*1 | Timing start: 0.5A to 80A (50/60Hz)*1 | | |
| Detection ser | isitivity (through current) | Counting stop: 0.2A (50/60Hz) or less | Timing stop: 0.2A (50/60Hz) or less | | |
| | Min. input signal width | 100ms | | | |
| Reset input | | Non voltage input using contacts or open collector connection | | | |
| | Input method (signal) | Input impedance, When shorted: | | | |
| | | Residual volta | • | | |
| Display meth | | 7-segment LCD | | | |
| Breakdown voltage (initial) | | | Between live and dead metal parts: 1,000V AC for 1 minute. | | |
| Insulation resistance (initial) | | Between live and dead metal parts: Min. 100MΩ (measured at 500 V DC) | | | |
| Protective construction*2 | | IEC Standard IP66 (only front panel with rubber gasket) | | | |
| Vibration resistance (Functional) | | 10 to 55 Hz: 1 cycle/min., signal amplitude of 0.15mm .006inch (10 min. on 3 axes) | | | |
| Vibration resistance (Destructive) | | 10 to 55 Hz: 1 cycle/min., signal amplitude of 0.375mm .015inch (1 hr. on 3 axes) | | | |
| | ince (Functional) | Min. 98m 321.522ft/s ² (4 times on 3 axes) | | | |
| Shock resistance (Destructive) Min. 294m 964.567ft/4 | | | | | |
| | | | 122°F (without frost or dew) | | |
| Storage temp | | -25 to +65°C -13 to +149°F (without frost or dew) | | | |
| Ambient humidity | | 35 to 85% RH (at 20°C non-condensing) | | | |
| Battery life*3 | | 7 years (at 25°C 77°F) | 10 years (at 25°C 77°F) | | |
| Mass (weight) | | Approx. 110g (Dedicated CT included) | Approx. 105g (Dedicated CT included) | | |
| | ximum cable diameter is 1 | | ry life is calculated based on the above conditions. | | |
| | | | s not a guarantee of actual battery life. | | |
| construction (IP66). Please use this as a guide for replacing the battery only. | | | | | |
| | | | ctual battery life may be shortened, depending on the utilization environment of | | |

the main unit.

2. Dedicated CT

| Item | Specification |
|---|---|
| Diameter of conductor to be measured | 10 dia. (max.) |
| Breakdown voltage (Initial value) | 1,000 Vrms AC for 1min: Between core and output connector terminal |
| Insulation resistance (Initial value) | Min. 100MΩ: Between core and output terminal (at 500V DC) |
| Allowable number of detachments/attachments | Approx. 100 times |
| Vibration resistance (Functional) | 10 to 55 Hz: 1 cycle/ min single amplitude of 0.15 mm .006 inch (10 min on 3 axes) |
| Vibration resistance (Destructive) | 10 to 55 Hz: 1 cycle/ min single amplitude of 0.375 mm .015 inch (1 h on 3 axes) |
| Shock resistance (Functional) | Min. 98 m 321.522 ft./s ² (4 times on 3 axes) |
| Shock resistance (Destructive) | Min. 294 m 964.567 ft./s ² (5 times on 3 axes) |
| Operating temperature range | -10°C to +50°C +14°F to 122°F (Without frost or dew) |
| Storage temperature | -20° C to $+60^{\circ}$ C -4° F to 140° F (Without frost or dew) |
| Mass (Weight) | Approx. 55g 1.94oz (trunk cable included) |
| Ambient humidity | 35 to 80% R.H. (at 20°C non-condensing) |

Note: For Eco-COUNT METER and Eco-HOUR METER, this CT is supplied together.

APPLICABLE STANDARDS

| F | | EN55011 Group 1 Class A EN55011 Group 1 Class A |
|-----|---|--|
| EMC | Static discharge immunity FF electromagnetic field immunity EFT/B immunity Conductivity noise immunity | EN61000-4-2 4 kV contact EN61000-4-3 10 V/m AM (80 MHz to 1 GHz) EN61000-4-4 1 kV (Signal line) EN61000-4-6 10 V/m AM (0.15 MHz to 80 MHz) EN61000-4-8 30 A/m (50Hz) |


PART NAME



| Lock switch (Mark on the unit ①) | (Terminal block side) ↓ (LCD side) | OFF* |
|-------------------------------------|--|------|
| | | |

Notes: 1. * Factory setting. 2. Make the switch setting before installing to panel. 3. Common to Eco-COUNT METER and Eco-HOUR METER.

DIMENSIONS




1. Main unit

1) Front reset key This key resets the count value of Eco-COUNT METER and elapsed time of Eco-HOUR METER. It does not work when the lock switch is ON. Note that frequent operation may shorten battery life. 2) Lock switch (Refer to chart on left)

Ineffective the front reset key


Note: LCD side is ON (reset ineffective); terminal block side is OFF (reset effective)

2. Dedicated CT



mm inch General tolerance: ±1.0 ±.039

2. Dedicated CT




Note: The trunk cable connects the main unit and dedicated CT. It is included with the main unit.

All Rights Reserved © COPYRIGHT Panasonic Electric Works Co., Ltd. 26/03/2013


INSTALLATION

1. Panel installation


1) One-touch installation type



2) Installation frame type



3) Panel cut-out dimensions



Note: When installing to a 4.5mm .177 thick panel, remove the rubber spacer first.


1. Panel installation

1) Installation using plastic magnet Attach the unit to the equipment case.




2) Installation via double-sided tape Use this method in places where a plastic magnet cannot be used or where installation strength is insufficient.

 3) Installation via clamp Clamp to one of the cables inside the equipment, etc.



Note: Take careful note of the precautions for use in the catalog or user's manual before using an Eco-COUNT METER or Eco-HOUR METER installed by one of the methods described above.


3. Terminal layout and wiring diagrams (Common to Eco-COUNT METER and Eco-HOUR METER)



Notes: 1. Terminal (2) and (4) are connected inside 2. The CT does not have polarity

OPTIONS






Note: We recommend using an intermediate power cable when attaching the dedicated CT to a non-"Y" split power cable


EXPLANATION OF OPERATION

KC2S Eco-COUNT METER 1. The number of power-ons is counted by sending through current through the dedicated CT.

2. When the number of power ons (measured value) reaches the full scale, it reverts to 0, and starts counting again from 0. 3. When the reset terminal input is set to on, the display will read "0". This does not count during reset input. 4. Use the reset key on the front of the unit to reset manually. The display will be blank while the reset key is being pressed.




Note: * If reset input is shut off while CT through current is on, the count will be set to 1.




RESET INPUT (Common to Eco-COUNT METER and Eco-HOUR METER)

1. Contact input

2. Transistor input (NPN transistor)





 Notes: 1. When using contact input, since current flow is small from reset input terminal ③, please use relays and switches with high contact reliability.
 When using transistor input, use the following as a guide for which transistors (Tr) to use for inputting. (Collector withstand voltage ≥ 50V, leakage current < 1µA)

NOTES

1. Main unit


1) Reset input

(1) Never apply voltage to reset input. This can cause damage to the internal elements. (2) Since the current flow is very small from reset input terminal (3), please use relays and switches with high contact reliability. When inputting a reset by a transistor's open collector use a transistor for small signals in which I_{CBO} is 1 μ A or less and always input with no voltage.

(3) When wiring, try to keep all the input lines to the reset inputs as short as possible and avoid running them together with high voltage and power transmission lines or in a power conduit.

Note that power cable floating capacitance in excess of 500 pF (10m on 2 mm² parallel cables) could cause malfunctions. Take particular care of inter-cable capacitance when using shielded cables.

2) How to reset multiple panel installation type units all at once.



Notes: 1. Use the following as a guide for choosing transistors used for input (Tr). Leakage current < 1μA

 Use as small a diode (D) as possible in the forward voltage so that the voltage between terminals 3 and 4 during reset input meets the standard value (0.5V).

(0.5V). (At IF = 20 μ A, forward voltage 0.1 V or less.)


2. Dedicated CT

 Measured power is AC (50 Hz/60 Hz).
 Will not function when used with DC power.
 When clamping to the power cable to be measured, clamp only one of the live wires.
 Avoid usage that bends the lead wire.
 When clamping, make sure that no dust or other foreign matter intercedes between the clamp and contact. Foreign matter could impact detection sensitivity.


3. Insulation sheet

Before using, please pull and remove the insulation sheet in the direction of the arrow. In consideration that the product might be stored for long periods without being used, an insulation sheet is inserted before shipping. Remove the insulation sheet and press the front reset key.

Installation frame type



One-touch installation type




4. Waterproof construction

The operation part is constructed to prevent water from entering the unit and a rubber gasket is provided to prevent water from entering the gap between the unit and the panel cutout.

There must be sufficient pressure applied to the rubber gasket to prevent water from entering.

Be sure to use the mounting screws when using the mounting frame (ATH3803). Attaching the one-touch installation type to a panel will not waterproof the panel surface.



5. Do not use in the following environments1) In places where the temperature changes drastically.

2) In places where humidity is high and there is the possibility of dew. (When dew forms the display may vanish and other display errors may occur.)

6. Cautions regarding battery replacement

 Remove wiring before replacing the battery. You may be electrocuted if you come into contact to a part where high voltage is applied.
 Make sure you are not carrying a static electric charge when replacing the battery.
 Battery replacement procedure
 Installation frame type

- Remove the battery cover ① from the case.
- (2) Remove the battery 2 from the side of the case.

The battery will come loose if you put the battery side face down and lightly shake the unit.

- (3) Before inserting wipe clean the surface of the battery.
 Insert the battery ④ with the + and - sides in the proper position.
- (4) After replacing the battery return the battery cover (5) to the case. Verify that the hook of the battery cover is properly engaged.

Before using press the reset key 6 on the front.

One-touch installation type


front.


- (1) Using a tool remove the up/down hook of the case ①.
- Pull the unit (2) away from the case.(2) Remove the battery (3) from the side of the unit. Do not touch the display or other parts.
- (3) Before inserting wipe clean the surface of the battery.

Insert the battery (5) with the + and – sides in the proper position.

(4) After replacing the batery return the unit (6) to the case. Verify that the hook of the case has properly engaged.
 Before using press the reset key (7) on the

Installation frame type





• One-touch installation type

